

Intensive Care Unit Built Environments: A Comprehensive Literature Review (2005–2020)

Health Environments Research
& Design Journal
2021, Vol. 14(4) 368-415
© The Author(s) 2021



Article reuse guidelines:

sagepub.com/journals-permissions
DOI: 10.1177/19375867211009273
journals.sagepub.com/home/her



Stephen Verderber, MArch, ArchD^{1,2} , Seth Gray, MD^{3,5,8},
Shivathmikha Suresh-Kumar, MArch⁴, Damian Kercz, MArch⁴,
and Christopher Parshuram, MB.ChB, DPhil^{2,3,5,6,7,8}

Abstract

Background: The intensive care environment in hospitals has been the subject of significant empirical and qualitative research in the 2005–2020 period. Particular attention has been devoted to the role of infection control, family engagement, staff performance, and the built environment ramifications of the recent COVID-19 global pandemic. A comprehensive review of this literature is reported summarizing recent advancements in this rapidly expanding body of knowledge. **Purpose and Aim:** This comprehensive review conceptually structures the recent medical intensive care literature to provide conceptual clarity and identify current priorities and future evidence-based research and design priorities. **Method and Result:** Each source reviewed was classified as one of the five types—opinion pieces/essays, cross-sectional empirical investigations, nonrandomized comparative investigations, randomized studies, and policy review essays—and into nine content categories: nature engagement and outdoor views; family accommodations; intensive care unit (ICU), neonatal ICU, and pediatric ICU spatial configuration and amenity; noise considerations; artificial and natural lighting; patient safety and infection control; portable critical care field hospitals and disaster mitigation facilities including COVID-19; ecological sustainability; and recent planning and design trends and prognostications.

¹ Centre for Design + Health Innovation, John H. Daniels Faculty of Architecture, Landscape and Design, University of Toronto, Ontario, Canada

² Institute for Health Policy, Management and Evaluation, Dalla Lana School of Public Health, University of Toronto, Ontario, Canada

³ Department of Critical Care Medicine, The Hospital for Sick Children, Toronto, Ontario, Canada

⁴ John H. Daniels Faculty of Architecture, Landscape and Design, University of Toronto, Ontario, Canada

⁵ The Hospital for Sick Children, Toronto, Ontario, Canada

⁶ Dalla Lana School of Public Health, University of Toronto, Ontario, Canada

⁷ Child Health Evaluative Sciences, SickKids Research Institute, Toronto, Ontario, Canada

⁸ Center for Safety Research, Toronto, Ontario, Canada

Corresponding Author:

Stephen Verderber, MArch, ArchD, Centre for Design + Health Innovation, John H. Daniels Faculty of Architecture, Landscape and Design, University of Toronto, Toronto, Ontario, Canada M5S 2J9; Institute for Health Policy, Management and Evaluation, Dalla Lana School of Public Health, University of Toronto, Toronto, Ontario, Canada MST 3M6.

Email: sverder@daniels.utoronto.ca

Conclusions: Among the findings embodied in the 135 literature sources reviewed, single-bed ICU rooms have increasingly become the norm; family engagement in the ICU experience has increased; acknowledgment of the therapeutic role of staff amenities; exposure to nature, view, and natural daylight has increased; the importance of ecological sustainability; and pandemic concerns have increased significantly in the wake of the coronavirus pandemic. Discussion of the results of this comprehensive review includes topics noticeably overlooked or underinvestigated in the 2005–2020 period and priorities for future research.

Keywords

literature review, intensive care units (ICUs), infection control, inpatient hospitals, family-centered care, evidence-based design (EBD), COVID-19 pandemic, patient-/person-centered care, staff effectiveness

Environmental design research has evolved significantly over the past 50 years to be recognized as a distinct discipline centered on the transactional relationship between the built environment, design excellence, and the improvement of the human condition. In the past 25 years, a subdiscipline of evidence-based research and design has focused on health and the built environment. This research is recognized as a distinct knowledge base addressing the spectrum of healthcare building types including hospitals, hospices, long-term care facilities, pediatric facilities, psychiatric and substance abuse treatment centers, and community-based outpatient clinics (Verderber, 2010). Correspondingly, the published literature has become increasingly complex and multifaceted, including the role of the built environment in infection control and the prevention of adverse medical events, furthered by the 2003 Institute of Medicine report *Crossing the Quality Chasm* (Zimring et al., 2013). As a consequence, it has become necessary to take stock of recent literature on the topic of the intensive care built environment. In the medical literature, the number and location of beds housed in intensive care units (ICUs) in hospitals have greatly expanded in the past decade (Wallace et al., 2017). A review of recent peer-reviewed quantitative and qualitative investigations and theoretical essays on critical care built environments can yield insight—particularly now—as the world endeavors to control and eradicate the virulent COVID-19 pandemic. This pandemic fueled an acceleration of new medical knowledge but has yet to fully impact

the realm of architecture. The generation of new knowledge on the ICU built environment can aid direct caregivers, patients, and families worldwide. This review of hospital ICUs, including neonatal ICUs (NICU) and pediatric ICUs (PICU), is focused on person–environment transactions. These settings are conceptualized here as constituting a typology, a prism of sorts, to achieve an overview of current best practices and theoretical perspectives vis-à-vis a comprehensive literature review. This systematic review consists of peer-reviewed research investigations, pertinent recent theoretical essays, and prognostications for the future.

This review of hospital ICUs, including neonatal ICUs (NICU) and pediatric ICUs (PICU), is focused on person–environment transactions. These settings are conceptualized here as constituting a typology, a prism of sorts, to achieve an overview of current best practices and theoretical perspectives vis-à-vis a comprehensive literature review.

This review directly builds upon a comprehensive literature survey on evidence-based healthcare design and the built environment published 13 years ago (R. L. Ulrich et al., 2008). In it, nearly 450 peer-reviewed research publications were summarized. It addressed patient safety issues, patient–staff outcomes, and insights on the interventional role of the physical environment.

Health status outcomes reviewed included nosocomial infections, medical errors, pain, sleep, stress, patient satisfaction, length of stay, privacy, communication, social supports, workplace injuries, staff stress, and satisfaction. Built environment interventions included single-bed rooms, access to daylight and appropriate lighting, views of nature, dedicated family zones within the patient room, noise reduction, workspace attributes, and acuity-adaptable patient rooms. ICUs were but one of many in-hospital units, freestanding building types, and user constituencies addressed. Since its publication, advances in critical care medicine, ecological sustainability, therapeutic benefits of person–nature connectivity, and best practices with respect to the COVID-19 global pandemic underscore the need for a comprehensive up-to-date review. The primary aim of the present review is to assess the current state of the art and science to better inform design choices to reduce adverse medical events, improve infection control and patient safety, better engage patients and families, examine person–nature interactions, and identify policies to improve caregiver work performance, satisfaction, and well-being.

Method

The methodology consisted of a broad review of published, peer-reviewed quantitative and qualitative investigations and essays. The first step consisted of a key word search to identify potentially relevant peer-reviewed publications. Forty key words were used, referring to patient and staff outcomes, that is, infection control, disease control, medical error, pain, sleep deprivation, respiratory disease, stress, privacy, and COVID-19. Second, referring to physical environment factors, that is, hospital; therapeutic gardens; COVID-19 field hospital; ICU design and layout; ICU unit layout; nursing station design; critical care medicine; critical care nursing; pulmonary medicine; ICU, NICU, and PICU design and features; acuity adaptability; and healthcare facilities. Third, referring to related issues, that is, staff productivity, stress, family-centered care, noise mitigation, nature, views, landscape, nature representations, patient safety, the future of the ICU, theoretical

prognostications, telemedicine, and ICU planning and design. Fourth, referring to healthcare facility infrastructure, that is, carbon neutral hospitals, sustainable design and operations, nontoxic materials, and hospital renovation and retrofitting. Extensive cross-searches were then conducted using combinations of key words and phrases through the JSTOR and Google Scholar databases and further searches combing multiple databases including EBSCO, ScienceDirect, PsychINFO, MEDLINE, Ovid, ProQuest, PubMed, Web of Science, Science Digest, and NIH Public Access. This search included any study or article that alluded or referred to the healthcare physical built environment in its title or abstract, published between January 2005 and February 2021. The decision was made at the outset to include both empirical and qualitative research investigations, as well as relevant theoretical and opinion essays, in order to broadly capture the scope, depth, and nuance of a rapidly evolving subject.

The initial search phase yielded 219 primary sources, subsequently reduced in the second-stage assessment to 147 peer-reviewed sources. These met or exceeded the team’s benchmark for rigor. In the third-stage assessment, these sources were further examined and reduced to a compendium of 135 sources (reported below). The research team carefully screened three types of sources: (1) empirically based studies that examine the role and impact of the built environment or natural environment on patient, staff, and/or family outcomes; (2) qualitative studies that examine these same relationships; and (3) theoretical essays that examine the relationship between intensive and critical care medicine, nursing best practices, pulmonary medicine, COVID-19, and the general planning and design of medical ICU built environments. Non-peer-reviewed white papers, research reports, minimum standards guidelines publications, and books on this subject were eliminated in the first wave of the screening process.

The final compendium was then structured into nine content categories deemed by the research team to best capture the current state of the art and science. The 2005–2020 period witnessed numerous innovations including acuity adaptability, debates between patient/family

privacy versus semiprivacy in the ICU patient room, telemedicine, acknowledgment of the therapeutic affordances of nature and landscape in the hospital setting, participatory planning and design tools to meaningfully elicit ICU design input from caregiver stakeholders, and ICU built environment impacts of the global COVID-19 pandemic that originated in China in late 2019.

Results

Table 1 contains the compendium of 135 research investigations, critical essays, and policy reviews presented in nine content categories: *nature engagement and outdoor views*—studies examining the influence of exposure to nature as well as representations of nature in critical care hospital inpatient units, with specific focus on measure of stress and stress reduction outcomes; *family accommodations in the ICU environment*—studies on the role of family involvement in the ICU experience and the influence of family input in ICU design and amenities provided; *ICU spatial configuration and amenity*—factors impacting the physical layout and associated amenities, associated staff affordances, and proxemic relationships, that is, travel distances, staff–patient sight lines, single versus semiprivate rooms; *noise considerations in ICU environments*—deleterious effects of excessive noise and involuntary distractions on patient and staff well-being, patient delirium, and the influence of noise mitigation measures on patient outcomes; *artificial and natural lighting in ICU environments*—adverse effects of excessive light on occupant well-being, the benefits of informative views, the utility of ventilation systems, and optimal ambient light levels on patient outcomes; *ICU patient safety and infection control*—studies addressing the types and prevalence of adverse medical events in critical care settings and measures to mitigate their occurrence and improve patient outcomes; *portable field hospitals and disaster mitigation including COVID-19*—the role, efficacy, and assessment of portable, critical care field hospitals for deployment in the aftermath of natural disasters and pandemics with specific focus on the global COVID-19 pandemic; *ICU ecological sustainability*—recent

advancements in energy efficiency, sustainable materials of construction, and resilient facility design and operation with direct applicability to critical care hospital units; and *recent design trends and prognostications*—essays on the present and future of critical care settings in hospitals, including therapeutic design affordances, and performance-based trends, that is, new technologies, acuity adaptability, and the ICU of the future.

Table 1 summarizes this knowledge compendium vis-à-vis the nine content categories with key background information and findings summarized. This consists of the author(s), date of publication, topic and scope of the study/essay, conceptualization of the built environment and the principal study setting, research design and sample (as applicable), outcome measures of well-being, physical environment features, and key findings of the investigation/discussion. As mentioned, only peer-reviewed publications are included. These empirical investigations and qualitative studies and essays emphasize day-to-day operations and the experience of frontline caregivers, patients, and family members. Early on, it was decided to not categorize NICU or PICU settings separately since many issues addressed in these settings were of equal relevance to the entirety of the built environment typology as defined above.

Nature Engagement and Outdoor Views

Wilson's biophilia hypothesis suggests that humans possess an "innate tendency to focus on life and life-like processes" and is often cited as a key consideration for using natural elements in the healthcare setting (Grinde & Patil, 2009; Minton & Batten, 2015). Despite U.S. Centers for Disease Control and Prevention guidelines suggesting that restriction of plants/flowers in hospital settings be limited to immunocompromised patients, live plants are often uniformly prohibited in ICUs (Sehulster et al., 2004). Eight studies were identified describing the integration of nature elements in an ICU or ancillary settings (waiting rooms and shared outdoor gardens) and patient ($n = 4$), staff ($n = 3$), and family ($n = 1$)

Table 1. Summary of ICU Built Environment Comprehensive Literature Review—Content Areas 1–9.

Citation	Research Design, Setting, and Sample	Physical Environment Attributes	Outcome Measures of Well-Being	ICU Built Environment Impact on Outcome(s)
I. Nature Engagement and Outdoor Views				
Beukeboom et al. (2012)	Nonrandomized comparative study. ICU/hospital waiting rooms. Single center; patients.	Live plants, artwork, and murals with nature themes	Survey of patient room attributes, environmental stress levels (State–Trait Anxiety Inventory)	Patients exposed to real plants and posters of plants reported a lower level of cognitive stress compared to respondents not exposed to these conditions.
Cordoza et al. (2018)	Randomized study. ICU/hospital. Single center; nursing staff.	Outdoor hospital garden	Staff assessment: Maslach Burnout Inventory, Present Functioning Visual Analogue Scale	Nurses and support staff who take breaks in an outdoor garden reported a significantly lower level of job performance burnout.
Kohn et al. (2013)	Cross-sectional observational study. Adult ICU. Single center; patients.	Windowed compared to windowless rooms; natural versus nonnature outdoor views	Length of stay, readmission rate, delirium occurrences, cost implications	Windowed patient rooms, including those affording natural views, do not significantly improve patient health status outcomes or reduce ICU care expenditures.
Pati et al. (2008)	Cross-sectional observational study. PICU. Multicenter; nursing staff.	Duration of exposure to outdoor view; view informational content (nature vs. nonnature)	Stress/Arousal Adjective Checklist survey; perceived chronic stress (Perceived Stress Scale)	Nursing staff exposed to exterior nature views experienced unchanged, or increased, alertness levels. Those whose alertness levels deteriorated experienced windowless or nonnature outdoor views.
Shepley et al. (2012)	Nonrandomized comparative study. Adult ICU. Single center; patients and staff.	Proximity to window, percent windowed wall area, intensity of sunlight transmission, and view informational content	Patient pain levels, ICU length of stay, staff errors, staff absenteeism, and room vacancy rates	Lighting levels, or exterior views alone, did not affect patients' perception of pain or length of hospitalization. For staff, increased lighting levels when combined with outdoor views were associated with decreased staff absenteeism.

(continued)

Table 1. (continued)

Citation	Research Design, Setting, and Sample	Physical Environment Attributes	Outcome Measures of Well-Being	ICU Built Environment Impact on Outcome(s)
Tanja-Dijkstra et al. (2008)	Randomized study. ICU/hospital. Multicenter; student respondents.	Photographs of hospital rooms with and without plants	Perceived visual attractiveness; stress level measurements (State–Trait Anxiety Inventory)	Participants exposed to photographs of hospital rooms with indoor plants reported significantly lower cognitive stress levels.
R. S. Ulrich et al. (2020)	Nonrandomized comparative study. Adult ICU. Single center; family members.	Outdoor hospital garden	Present Functioning Visual Analogue Scale stress assessment	Cognitive stress was reduced following exposure to an outdoor garden and indoor settings affording exposure to the outdoors. Breaks taken in the garden resulted in significantly higher satisfaction levels.
Wunsch et al. (2011)	Cross-sectional observational study. Adult ICU. Single center; patients.	Presence of a window in patient room compared to windowless rooms	Neurologic disability; heating, ventilation, and air-conditioning (HVAC) system; command response time; gastrostomy tube or tracheostomy procedures; ICU/hospital length of stay; and mortality rate	Presence of a window in the patient room did not significantly improve outcomes for adult patients with subdural hemorrhage admitted to the ICU.
2. Family Accommodations in the ICU Environment				
Davidson et al. (2007)	Literature review. Adult ICU, PICU, and NICU. Multicenter; family members/visitors.	Single versus multibed rooms, directional signage, wayfinding	Visitation behavior, family involvement, satisfaction, and perceived stress	Recommendations: Encourage open visitation policies, single-bed rooms, navigable wayfinding systems to reduce family stress levels and foster integration in the intensive care milieu.
Davidson et al. (2017)	Systematic literature review. ICU, PICU, and NICU. Multicenter; family members.	Noise sources, hygiene stations, sleep amenities for families	Family member engagement and satisfaction	Recommendations: Noise reduction policies, single-bed patient rooms, sleep accommodations for families, and a family-centered care accommodation checklist.

(continued)

Table 1. (continued)

Citation	Research Design, Setting, and Sample	Physical Environment Attributes	Outcome Measures of Well-Being	ICU Built Environment Impact on Outcome(s)
Day et al. (2013)	Cross-sectional observational study. Adult ICU. Single center; family members.	Multiple locations sampled on unit where family members/visitors sleep	Family member–visitor sleep disturbances, anxiety level, and fatigue	Majority of family members of ICU patients reported in-hospital sleep disturbances; 27% reported having slept in a waiting room.
Fridh et al. (2009)	Cross-sectional observational study. Adult ICU. Single center; nurses.	Privacy measurements in patient rooms	Qualitative assessment of physical setting obstacles encountered in caring for the severely ill	The ICU physical setting impacts the ability to provide dignified end-of-life care for patients and their families. Insufficient privacy reported as the most prevalent obstacle encountered.
Franck et al. (2015)	Cross-sectional observational study. PICU and NICU. Multicenter; family members.	Various locations where family members of ICU patient sleep	Family self-reported sleep locations and satisfaction	In PICUs, significant number of parents sleep in child’s room, whereas most NICU parents sleep at home. Hospitals with family accommodation programs are associated with higher parent satisfaction level.
Huynh et al. (2020)	Nonrandomized comparative study. Adult ICU. Single center; family members.	Space in the patient room available for family/visitor use	Evening and overnight family–visitor patient room usage	The provision of dedicated space for family/visitors in the patient room is associated with increased evening and overnight usage.
Jongerden et al. (2013)	Nonrandomized comparative study. Adult ICU. Single center; patients and family.	Single-bed patient rooms, privacy, outdoor views, natural daylight, and noise sources	Patient and family satisfaction	Key recommendations: Improve noise reduction, orient bed to provide exposure to natural daylight, and provide family accommodations to foster greater patient and family involvement.
Macdonald et al. (2012)	Cross-sectional observational study. PICU. Single center; family, staff, and patients.	Noise sources, privacy measurement	Family visitation behaviors; staff and patient assessments of physical setting	Family and visitors prefer PICU policies allowing for more meaningful participation in the patient hospitalization experience.

(continued)

Table 1. (continued)

Citation	Research Design, Setting, and Sample	Physical Environment Attributes	Outcome Measures of Well-Being	ICU Built Environment Impact on Outcome(s)
Rashid (2010)	Narrative review. Adult ICU. Multicenter; staff and family.	Physical setting amenities and appearance	Family member integration; healing culture	The ICU physical setting is a primary therapeutic modality in the overall hospitalization experience of family and visitors.
Rippin et al. (2015)	Nonrandomized comparative study. Adult ICU. Single center; nurses and family.	Physical attributes of family-only compared to shared staff–family corridors adjacent to ICU	Frequency, time, location, and type of nurse–family interaction	Increased interactions were identified in shared staff–family corridors, with majority initiated by family members. Nurses report loss of territorial workflow control in this condition.
Peterson et al. (2020)	Nonrandomized observational study. Adult ICU. Single center; family members.	Noise sources, waiting room size, private spaces, and restrooms	Family satisfaction	Quiet spaces, sufficiently large waiting room, availability of private space, and proximity to restrooms associated with higher family satisfaction level.
Stremmer et al. (2014)	Cross-sectional observational study. PICU. Single center; family members.	Parent sleep locations and amenity: patient room, parent room/ lounge, hotel, and private residence	Sleep–wake patterns and self-reports of fatigue and sleeplessness	Acute sleep deprivation was reported on more than 25% of days/evenings; long wake times were reported in off-site hotels, in on-site parent room/lounge, and one’s private residence.
3. ICU Spatial Configuration and Amenity Apple (2014)	Nonrandomized comparative study. Adult ICU. Multicenter; staff and patients.	Hybrid patient room module: Single-bed with staff monitoring space	Staff-to-patient visibility, privacy, staff collaboration, and family engagement	Open-view rooms increase caregiver and family visibility but result in more noise and reduced privacy. Private modules assessed as quieter, but staff feel less visually connected to patient.

(continued)

Table 1. (continued)

Citation	Research Design, Setting, and Sample	Physical Environment Attributes	Outcome Measures of Well-Being	ICU Built Environment Impact on Outcome(s)
Arenson et al. (2013)	Nonrandomized comparative study. Adult ICU. Single center; patients.	Single-bed rooms with windows and multibed rooms without windows	Patient delirium occurrences	No significant difference in delirium reported between private versus multibed rooms for patients 65 and older. Patients under 65 experienced highest number of days with delirium in multibed windowless rooms.
Bosch et al. (2012)	Nonrandomized comparative study. NICU. Single center; staff.	Hybrid mix of single-bed and multibed patient rooms	Staff assessment of workplace environmental support	Nurses reported reduced job stress, associated with improved level of parental privacy, as key benefits of single-bed NICU rooms.
Cai & Zimring (2012)	Nonrandomized comparative study. Adult ICU. Single center; staff.	Nursing station types: Centralized, decentralized, and hybrid	Spatial metrics, patient visibility, team and peer proxemics, and nursing team communications	Each nursing station type fosters a unique staff communication pattern. Consider team-based and peer-to-peer proxemics when evaluating various types of ICU workspaces.
Catrambone et al. (2009)	Cross-sectional observational study. Adult ICUs. Multicenter; staff and patients.	Unit configuration; patient visibility, proxemics, single-bed rooms, and floor surface type	Assessment of multiple unit types and design attributes	Four unit types comprise the majority of ICU types in the United States, representing diverse levels of patient–staff visibility, proxemic relationships, design amenities, and caregiving policies.
Caruso et al. (2014)	Nonrandomized comparative study. Adult ICU. Single center; patients.	Single versus multibed patient rooms	Delirium occurrences: Coma/delirium-free days, first day in delirium, and motoric subtypes	ICU patients admitted to single-bed rooms experience lower occurrence of delirium compared to patients in multibed rooms.

(continued)

Table 1. (continued)

Citation	Research Design, Setting, and Sample	Physical Environment Attributes	Outcome Measures of Well-Being	ICU Built Environment Impact on Outcome(s)
Copeland & Chambers (2017)	Nonrandomized comparative study. Adult ICU. Single center; nursing staff.	Centralized versus decentralized nurses station	Job satisfaction, on-shift walking distances, and personal energy expended at work	For nurses, a decentralized ICU layout contributed to reduction in on-shift walking distances. Job satisfaction level was higher in decentralized versus centralized units.
de Matos et al. (2020)	Nonrandomized comparative study. Adult ICU, Single center; staff and family members.	Single versus multibed patient rooms	Staff and family stress, staff burnout, family satisfaction	Single-bed ICU rooms preferred by family yet yield higher staff stress level, although no difference was reported in staff burnout rates between single versus multibed rooms.
Fay et al. (2019)	Systematic review. ICU/ hospital. Multicenter; nursing staff and patients.	Centralized versus decentralized nursing station	Patient well-being, nursing job satisfaction, travel distances, and energy expended	Decentralized nursing stations were associated with higher patient satisfaction. Staff teamwork and communication levels reported to decline in decentralized nurses stations.
Garavais et al. (2018)	Nonrandomized comparative. Adult ICU.	Spatial layouts and visibility factors	Team communications as a function of unit visibility	Improved unit visibility, results in improved team communications
Gurses and Carayon (2009)	Cross-sectional observational study. Adult ICU. Single center; nursing staff	Noise sources, workplace spatial layout, support amenities	Staff assessment of workplace performance obstacles/barriers	Routine work performance obstacles identified: Excessive noise, overcrowding, insufficient space for charting, and disorganized work zone.
Hadi & Zimring (2016)	Cross-sectional study. Adult ICU. Multicenter; nursing staff.	Corridor width, length, and unit configuration	Nurse-to-patient visibility and floor plan/unit configuration analysis	Wider corridors were associated with significant increase in patient room visibility from adjacent nursing staff workspaces.

(continued)

Table 1. (continued)

Citation	Research Design, Setting, and Sample	Physical Environment Attributes	Outcome Measures of Well-Being	ICU Built Environment Impact on Outcome(s)
Hamilton et al. (2018)	Policy review/essay. Adult ICU. Multicenter; nursing staff and patients.	Centralized versus decentralized units, corridor width, and unit size	Travel distances, staff visibility of patients, team communication, and patient safety	Travel distances, patient visibility, and staff communication factors were examined relative to corridor width/type in decentralized versus centralized ICUs.
Leaf et al. (2010)	Cross-sectional observational study. Adult ICU. Single center; patients and staff.	Room attributes, size, and location on unit	Length of stay, number of nonventilator days, and mortality rate	Severely ill patients experienced higher mortality rate when admitted to patient rooms low in visibility from nursing work core.
Lu & Zimring (2011)	Cross-sectional observational study. Adult ICU. Single center; staff.	Room attributes, size, and location on unit	Comparative assessment of targeted versus untargeted patient viewing practices	Physicians and nurses engage in different strategies and methods to visually monitor their patients.
Lu et al. (2014)	Cross-sectional observational study. Adult ICU. Adult ICU patients.	Patient room visibility and field of vision from nursing station	Mortality levels	Among the most severely ill patients, not having a direct field of view from the nearest nurses station accounted for 33.5% of the variance in mortality.
O'Hara et al. (2018)	Cross-sectional observational study. PICU; staff.	Unit configuration and nursing staff work zones	Distance matrices; field-of-view analysis of visibility levels and caregiver team interactions	ICU layout can enhance caregiver team interactions and nursing staff field of view of patients from the work core.
Pati et al. (2015)	Cross-sectional observational study. Adult ICU. Multicenter; nursing/support staff.	Centralized versus decentralized nurses station	Staff assessment of work productivity, on-shift travel distances, stress, and team communications	Decentralized ICU layouts foster more patient health status monitoring, medication distribution, and supply room utilization. Long walking distances result in decreased nursing staff team collaboration.

(continued)

Table 1. (continued)

Citation	Research Design, Setting, and Sample	Physical Environment Attributes	Outcome Measures of Well-Being	ICU Built Environment Impact on Outcome(s)
Rashid et al. (2014)	Nonrandomized comparative study. Adult ICU. Multicenter; patients.	Unit configuration and physical attributes	Staff assessment of team communications, collaboration, and patterns of use	Staff communication levels and patterns of use/activities are impacted by ICU unit configuration attributes and design amenity.
Real et al. (2016)	Cross-sectional observational study. ICU/hospital. Single center; nursing and support staff.	Centralized versus decentralized nurses station	Teamwork, communications, and on-shift travel distances	Decentralized nurses stations were found to be associated with a reduced level of nurse-to-nurse collaboration and communications.
Stevens et al. (2012)	Nonrandomized comparative study. NICU. Single center; staff and patients.	Single-bed, multibed patient rooms	Staff assessment: Noise, illumination level, enteral feeding, parent satisfaction, nurse anxiety scores, and sleep patterns	Private patient rooms associated with lower nursing anxiety scores due to decreased time required to perform full enteral feeding procedure; no change in anxiety detected in rooms rated low in noise and illumination level.
Swanson et al. (2013)	Nonrandomized comparative study. NICU. Single center; staff and family members.	Single-bed, multibed patient rooms	Staff assessment: Teamwork, communications, and patient safety	Nurse satisfaction scores associated with single-bed ICU rooms initially high but decline over time. Parents reported higher satisfaction compared to nursing staff.
Zborowsky & Hellmich (2011)	Opinion essay and literature review. Adult ICU; staff, patients, and family members.	Unit configuration and patient room physical attributes	Patient safety and family and staff satisfaction	Decentralized ICUs were associated with lower frequency of physician–nurse communications and increase in the interruption of routine work responsibilities.

(continued)

Table I. (continued)

Citation	Research Design, Setting, and Sample	Physical Environment Attributes	Outcome Measures of Well-Being	ICU Built Environment Impact on Outcome(s)
4. Noise Considerations in ICU Environments				
Brandon et al. (2007)	Nonrandomized comparative study. NICU. Single enter; nursing and support staff.	Automatic towel dispensers; staff audio communication system as noise sources	Ambient noise mitigation	Introduction of new equipment: Automatic paper towel dispensers and new staff audio communications system significantly increased ambient noise levels in a NICU.
Carvalho et al. (2005)	Cross-sectional observational study. PICU. Single center; staff and patients.	Noise source, generation, and periodic data sampling	Ambient sound measurement	Ambient noise levels recorded of 60–70 dBA (max 120 dBA). Higher noise levels were recorded during day and in admission/shift transition. Staff conversation is the most frequent source of noise.
Carvalho et al. (2005)	Nonrandomized comparative study. NICU. Single center; staff and patients.	Noise sources, single versus multibed patient rooms	Ambient noise standards	Recorded noise levels were higher than industry-wide recommended standard. Single-bed patient rooms generate significantly lower noise levels versus multibed rooms.
Chawla et al. (2017)	Nonrandomized comparative study. NICU. Single center; staff, patients, and family members.	Alarm equipment sound levels generated during “quiet times” on unit	Ambient noise intervention	A reduced unit-wide alarm system ambient sound level resulted in a decrease in ambient noise during quiet periods in a NICU.
H. L. Chen et al. (2009)	Nonrandomized comparative study. NICU. Single center; patients.	Noise sources, open patient rooms	Ambient sound standards	In open-bed patient areas, noise levels generated were significantly above industry-wide recommended maximum levels.
Christensen (2007)	Cross-sectional observational study. Adult ICU. Single center; patients	Noise sources and multibed patient rooms	Ambient noise measurement	The mean recorded dBA was 56 (max 80 dBA). Higher noise levels were consistently recorded during weekdays in the ICU.

(continued)

Table 1. (continued)

Citation	Research Design, Setting, and Sample	Physical Environment Attributes	Outcome Measures of Well-Being	ICU Built Environment Impact on Outcome(s)
Johansson et al. (2012)	Cohort observational study. Adult ICU. Single center; patients.	Noise sources and multibed rooms on multiple days/times	Ambient sound measurement	It was found the mean sound level was 53 dBA (maximum 82–101 dBA). Patients recounted sounds during ICU hospitalization and did not report excessive noise levels.
Kawai et al. (2019)	Nonrandomized comparative study. PICU. Single center; patients.	Single-bed and multibed patient rooms	Ambient sound measurement	It was found the mean noise level was 52.8 dBA (maximum 67 dBA). Louder sound levels were routinely experienced during the day.
Kol et al. (2015)	Nonrandomized comparative study. PICU. Single center; patients.	Single-bed and multibed patient rooms	Ambient sound measurement	Patients consistently experienced lower ambient noise levels in single-bed PICU rooms.
Kramer et al. (2016)	Nonrandomized comparative study. PICU. Single center; patients and staff.	Single-bed and multibed patient rooms	Ambient sound measurement	A mean noise level of 62 dB was recorded (maximum 82 dBA), with no significant differences between single versus multibed rooms. Parents and staff view health status monitor equipment as key noise generator.
Lasky & Williams (2009)	Nonrandomized comparative study. NICU. Single center; patients and staff.	Single-bed and multibed patient rooms	Ambient sound standards	Documented noise level increased over time, averaging 56.44 dBA; average ambient noise level was within the AAP-recommended level 50.5% of the time across typical 24-hr period.

(continued)

Table 1. (continued)

Citation	Research Design, Setting, and Sample	Physical Environment Attributes	Outcome Measures of Well-Being	ICU Built Environment Impact on Outcome(s)
Luetz et al. (2016)	Nonrandomized comparative study. Adult ICU. Single center; patients and staff.	In-room equipment, finish surfaces, and materiality as noise sources	Ambient noise mitigation	Noise-reducing headwalls, sound-absorbing materials, and two-door patient room–corridor isolation reduce average-to-maximum noise levels and sound peaks (quieter at night and louder during day).
Macedo et al. (2009)	Cross-sectional study. Adult ICU. Multicenter; patients and staff.	Two adult ICUs and one adult cardiac ICU	Ambient sound measurement	Noise levels in sampled adult ICUs were found to be consistently in excess of recommended industry-wide standards.
Matook et al. (2010)	Cross-sectional study. NICU. Single center; patients and staff.	Multiple locations and times of day sampled	Ambient noise measurement	Sound levels were found to vary significantly as a function of the location sampled in the NICU. Day shifts generate higher noise levels than night shifts.
Ryherd et al. (2008)	Cross-sectional study. Adult ICU. Single center; nursing and support staff.	Multibed patient room staff survey assessing perceived noise levels	Ambient noise and staff assessment	Nurses reported perceived noise contributes to irritation, fatigue, concentration difficulty, and headaches. Average noise generated in direct patient care was 53–58 dBA; for staff, dosimeter noise generated was 65–71 dBA.
Wang et al. (2013)	Nonrandomized comparative study. Adult ICU. Single center; nursing and support staff.	New ICU facility with a designated service corridor	Ambient noise intervention	Lower noise levels resulted in an ICU with an adjacent, dedicated service corridor. Staff reported their reduced stress was due to the presence of the adjacent corridor.

(continued)

Table 1. (continued)

Citation	Research Design, Setting, and Sample	Physical Environment Attributes	Outcome Measures of Well-Being	ICU Built Environment Impact on Outcome(s)
5. Artificial and Natural Lighting in ICU Environments				
Kohn et al. (2013)	Cross-sectional observational study. Adult ICU. Single center; patients.	Windowed versus windowless rooms; nature versus nonnature view informational content	Length of ICU stay, readmission rate, delirium occurrences, and cost ramifications	Patient rooms with windows affording outdoor views of nature do not significantly improve patient outcomes nor reduce overall costs of ICU hospitalization.
Lasky & Williams (2009)	Cohort observational study. NICU. Single center; patients and staff.	Single-bed and multibed patient rooms	Ambient illumination levels	Illumination level reported to increase over time on shift, averaging 70.56 lux; illumination level measurements found to be within AAP recommendations 99% of the time.
Morag & Ohlsson (2016)	Systematic review. NICU. Multicenter; patients and staff.	Cycled light patterns: Continuous bright light and near darkness conditions	Length of stay and growth rate in preterm infants	Cycled illumination strategies, compared to continuous bright lighting and near darkness condition, shortened hospital length of stays for preterm neonates.
Rompaey et al. (2009)	Nonrandomized comparative study. Adult ICU. Multicenter; patients.	Single-bed and multibed patient rooms; natural daylight	Delirium occurrences	The absence of visible natural daylight was identified as a high risk factor in the occurrence of delirium in adult ICU patients.
Shepley et al. (2012)	Nonrandomized comparative study. Adult ICU. Single center; patients and staff.	Bed distance from window, window-wall area ratio, sunlight intensity, and views of nature	Patient pain levels, length of stay, staff medical errors, absenteeism, and room utilization	Neither natural daylight level nor the presence of views of nature affected pain perception or length of stay. Increased daylight level and outdoor views were associated with a decrease in staff absenteeism and patient room occupancy.

(continued)

Table 1. (continued)

Citation	Research Design, Setting, and Sample	Physical Environment Attributes	Outcome Measures of Well-Being	ICU Built Environment Impact on Outcome(s)
Simons et al. (2016)	Randomized study. Adult ICU. Single center; patients.	Patient room illumination	Incidence of delirium; dynamic light intervention	Trial concluded prematurely due to futility. Dynamic light application method found ineffective in recording cumulative delirium occurrences.
Stevens et al. (2007)	Nonrandomized comparative study. NICU. Single center; patients.	Single-bed and multibed patient rooms	Ambient illumination and physiologic parameters in neonatal patients	Lower minimum/maximum illumination levels were identified in single-bed NICU rooms. Less neonatal periodic breathing issues and awake time occurred in low-illumination conditions.
Verceles et al. (2013)	Cross-sectional study. Adult ICU. Single center; patients.	Cardinal direction orientation and ambient illumination level	Nonventilator usage days; sedative, analgesic, and neuroleptic medications	Cardinal direction room orientation factors and ambient illumination levels were not associated with ICU patient outcomes.
Zores et al. (2018)	Prospective observational study. NICU. Single center; patients.	Illumination levels	Infant behaviors; sleep–awake patterns	Minor variation in illumination levels were found to have a disruptive impact on preterm infants' sleep/awake behaviors.
Zores-Koenig et al. (2020)	Systematic narrative review. NICU. Multicenter; patients.	Illumination levels, light protection device, and cycled lighting protocols	Infant sleep/awake behaviors, rate of growth, and length of hospitalization	Variations in light level should be graduated, not abrupt. Light protection/screening should be utilized for infants under 32 weeks of age; overexposure high light levels can be harmful; predischarge, cycled lighting is recommended.

(continued)

Table 1. (continued)

Citation	Research Design, Setting, and Sample	Physical Environment Attributes	Outcome Measures of Well-Being	ICU Built Environment Impact on Outcome(s)
6. ICU Patient Safety and Infection Control				
Bloemendaal et al. (2009)	Nonrandomized comparative study. Adult ICU; Multicenter; patients.	Single-bed and multibed patient rooms	Acquisition of MRSA colonization during ICU admission process	Lower rate of MRSA acquisition reported in single-bed patient rooms.
Bracco et al. (2007)	Nonrandomized comparative study. Adult ICU. Single center; patients.	Single-bed and multibed patient rooms	Acquisition of MRSA, pseudomonas, and Candida spp. during ICU admission process	Lower relative risk of MRSA infection, Pseudomonas aeruginosa, and Candida spp. acquisition reported in single-bed rooms compared to multibed patient rooms.
Carayon et al. (2020)	Basic science/engineering. General; patients/staff.	Human factors and ergonomics	Predictors of patient safety	The ICU/hospital setting can foster patient safety through the systematic incorporation of human factor and ergonomics principles in systems design engineering models.
Cepeda et al. (2005)	Nonrandomized comparative study. Adult ICU. Multicenter; patients.	Single-bed isolation rooms and multibed rooms	MRSA cross-infection rates	Relocating MRSA-positive patients to single-bed rooms or to cohorted open bays does not significantly reduce cross-infection rates.
Leaf et al. (2010)	Cross-sectional observational study. Adult ICU. Single center; patients.	Patient room proximity, visibility, and nurses station	Length of stay, ventilator-free days, and mortality rate	Severely ill patients experienced higher hospital mortality rates when admitted to low staff-to-patient visibility level patient rooms.
Levin et al. (2011)	Nonrandomized comparative study. Adult ICU. Single center; patients.	Single-bed and multibed patient rooms	Infection rate with antibiotic-resistant organisms	Patients admitted to single-bed rooms found to experience fewer infections caused by antibiotic-resistant organisms.

(continued)

Table 1. (continued)

Citation	Research Design, Setting, and Sample	Physical Environment Attributes	Outcome Measures of Well-Being	ICU Built Environment Impact on Outcome(s)
Malenbaum et al. (2008)	Research review. ICU/hospital. General; patients.	Environmental stimuli: Light, nature, and sound	Patient pain level	Exposure to light, nature, and virtual reality (VR) protocols can help in reducing pain and aid in pain management during hospitalization.
Pettit et al. (2014)	Nonrandomized comparative study. Adult ICU. Single center; patients.	High versus low staff visibility rooms; proximity to nursing station	Mortality rate	For trauma patients, admission to patient rooms with high staff visibility was not associated with improved patient outcomes.
Reynolds et al. (2020)	Experiment. ICU/hospital. General; patients/staff.	Whole-room atomizer disinfection system	Bacterial counts as measured by bacterial tracers	Use of room atomizer disinfection systems, in tandem with manual cleaning protocols, was found to be superior to manual cleaning protocols alone.
Stiller et al. (2017)	Cross-sectional study. Adult ICU. Multicenter; patients.	Single-bed and multibed patient rooms; hand sanitizer dispensers; window operability	Nosocomial infection rate	Intercorrelations were identified between specific ICU design attributes and patient infection rates; recommended HVAC and ventilation systems and features.
Teltsch et al. (2011)	Nonrandomized comparative study. Adult ICU. Multicenter; patients.	Single-bed and multibed patient rooms	Nosocomial infection rate	The conversion to all single-bed ICU rooms was found to reduce the occurrence of nosocomial patient infections.
7. Portable Field Hospitals and Disaster Mitigation Including COVID-19				
Auerbach et al. (2020)	Cross-sectional study. Adult ICU. Multicenter; COVID-19 patients.	Respiratory isolation unit (RIU)	Personal protective equipment (PPE), unit retrofitting	Best practices presented to rapidly retrofit existing hospital units into RIUs in support of PPE requirements in emergency care.
Blackwell & Bosse (2007)	Case study/policy. Mobile ICU. Vehicular; patients and staff.	Mobile critical care clinic—Hurricane Katrina	Staff assessment, patient well-being, and mortality rate	MED-I is a vehicular first response critical care facility with onboard mobile field hospital capabilities.

(continued)

Table 1. (continued)

Citation	Research Design, Setting, and Sample	Physical Environment Attributes	Outcome Measures of Well-Being	ICU Built Environment Impact on Outcome(s)
Burnweit & Stylianos (2011)	Case study/policy. NICU. Single center; staff and disaster victims.	Field hospital installation—Haiti	Staff self-assessment of stress; facility occupancy and mortality rate	Deployment of a portable NICU modular field hospital was effective—a strategy advocated for postdisaster strike zones in the future.
Capolongo et al. (2020)	Cross-sectional study: United States and ICU/hospital. Multicenter; facilities.	Hospital design resiliency—United States, Italy, and Austria	Futureproofing, functional performance, user participation, regional networking, patient safety, HVAC systems, finish materials, and IT	Resilient hospital design and daily operational policies can increase critical care delivery capacity and contribute to positive staff and patient outcomes.
L. Chen et al. (2021)	Case study/policy. ICU/hospital. Single center; patients and staff.	Wuhan Leishenshan 1,600-bed COVID-19 surge hospital.	Patient safety, mortality rate, and staff assessment	Rapid construction of a hospital for COVID-19 critical care was achieved using building information modeling and prefabricated modular construction methods.
Z. Chen et al. (2020)	Policy review. ICU/hospital. Multicenter; patients and staff.	COVID-19 mobile field hospitals—China	Intubated patients and infection control	Mobile modular field hospitals were proven effective in isolating the sickest COVID-19 patients located in proximity to existing medical centers.
S. Chen et al. (2020)	Case study/policy. ICU/hospital. Single center; patients and staff.	Fangcang field hospital and converted sports stadium—Wuhan, China	Patient safety, mortality rate, staff assessment, and performance	The rapidly constructed, modular prefab Fangcang Hospital was demonstrated to provide effective critical care while meeting COVID-19 emergency care requirements.

(continued)

Table 1. (continued)

Citation	Research Design, Setting, and Sample	Physical Environment Attributes	Outcome Measures of Well-Being	ICU Built Environment Impact on Outcome(s)
des Déserts et al. (2020)	Case study/policy. ICU/hospital. Single center; patients and staff.	30-bed portable military field hospital—France	Patient well-being and staff assessment	The deployment of the EMRSSA mobile field hospital was demonstrated to be effective without compromising patient safety nor the well-being of direct staff caregivers.
Doshi et al. (2020)	Case study/policy. Adult ICU. Single center; staff and patients.	Telehospital and unit configuration and design	Health status and staff assessment	Telemedicine was demonstrated to support patient care and aid clinicians by conserving scarce fiscal, medical, equipment, and ancillary staff resources.
Fang et al. (2020)	Case study/policy. ICU/hospital. Single center; patients and staff.	Fangcang field hospital and converted stadium—Wuhan, China	Isolation, disease containment, mortality rate, and staff performance	A case study of the rapid adaptation of a large-scale public venue into a host facility for a modular, portable COVID-19 critical care unit.
Flinn et al. (2020)	Case study/policy. Adult ICU. Multicenter; patients and staff.	Biocontainment unit(BCU)	Staff first response performance and disease containment	The value of BCUs was demonstrated in the diagnosis and treatment of COVID-19 patients. BCUs preposition healthcare facilities for future pandemics and related crises.
Fortis et al. (2014)	Systematic review essay. Adult ICU. Multicenter; staff and patients.	Telemedicine-based ICU versus conventional ICU—United States	Staff performance and patient well-being	Advocates an innovative concept utilizing off-the-shelf technology to unify and standardize the ICU built environment.
Keenan (2020)	Policy review. Adult ICU. Multicenter; staff and patients.	ICU design and archival data	Facility resiliency and adaptive capacity	The resilience and adaptive capacity of the built environment are central components in managing the myriad challenges associated with critical care hospital units.

(continued)

Table 1. (continued)

Citation	Research Design, Setting, and Sample	Physical Environment Attributes	Outcome Measures of Well-Being	ICU Built Environment Impact on Outcome(s)
Kreiss et al. (2010)	Case study/policy. ICU/field hospital. Single center; disaster victims and first response staff.	Portable hospital—Haiti	Quality control, patient well-being, and staff satisfaction	Highlights the minimization of staff fatigue/burnout, surge capacity, and critical care field hospital facility design as major emergency response planning determinants.
Lee et al. (2019)	Policy review. Portable field hospitals. Multicenter; disaster victims and first response staff.	Archival data, portable field hospitals, and global humanitarian missions	Staff performance and patient health status	Critical care field hospitals must support human dignity, organizational accountability, and political impartiality; provide high-quality care; and be rapidly deployed and commissioned in postdisaster strike zones.
Lenaghan & Schwedhelm (2015)	Case study/policy. Adult ICU/BCU. Single center; staff.	BCU	Staff assessment	Meaningfully engage direct care providers in selecting the facility planning and design team and then charge direct caregivers as key participants in the facility planning and design process.
Louri et al. (2020)	Case study/policy. COVID-19 field hospital. Single center; staff.	Portable 130-bed military field hospital—Bahrain	Infection control, ventilation, transiting, commissioning, and siting	Recommendations for site selection, facility design, construction, deployment, infection controls, circulation, materials management, and waste disposal.
Owens et al. (2005)	Case study/policy. NICU. Single center; first response staff and disaster victims.	Deployable Rapid Assembly Shelter/ Surgical Hospital—Iran	Healthcare quality control, cultural values and norms, and knowledge transfer	Sociocultural norms and traditions of high priority in NICUs in postdisaster zones; facility features and equipment recommendations are provided.

(continued)

Table 1. (continued)

Citation	Research Design, Setting, and Sample	Physical Environment Attributes	Outcome Measures of Well-Being	ICU Built Environment Impact on Outcome(s)
Pucher et al. (2014)	Nonrandomized comparative study. Adult ICU/hospital. Single center; staff.	Physical and virtual facilities—UK	Environmental stress and staff assessment	VR was demonstrated as effective tool in training and pretesting of hospitals and associated infrastructure in preparation for mass casualty events.
Santos et al. (2020)	Case study/policy. Adult ICU. Multicenter; patients and staff.	COVID-19 treatment facilities	Patient safety and environmental control systems	Recommended best practices are adapted in in-hospital COVID-19 ICUs with respect to design and operation of HVAC systems.
Sonmez & Cavka (2020)	Case study/policy. COVID-19 surge hospitals. Multicenter; facilities.	Review of nine facility surge hospital prototypes	Portable prefabricated modularity	Design recommendations in the planning, design, construction, and operation of COVID-19 treatment facilities.
Wosik et al. (2020)	Policy review. Adult ICU. Multicenter; staff and patients.	Archival data and hospital-based telehealth care	Virtual telehealth, staff performance, and patient outcomes	Advocates the adoption of high-tech virtual healthcare diagnosis and treatment capabilities in U.S. hospitals to expand medically underserved populations' access to care.
Zangrillo et al. (2020)	Case study/policy. Adult ICU. Single center; staff and patients.	Retrofitting in-hospital ICU for COVID-19 healthcare	Staff assessment and patient safety	A redesigned in-hospital resulted in an increase in ICU healthcare services to a community in Italy hard-hit by COVID-19.
Zhou et al. (2020)	Case study/policy. ICU/NICU/PICU. Single center; facilities.	Huoshenshan Hospital—Wuhan, China	Construction of 10,000-bed temporary modular COVID-19 surge hospital	Modular field hospital expressly constructed for the COVID-19 pandemic. Mortality rates and infection control were achieved in this specialized pandemic healthcare facility.

(continued)

Table 1. (continued)

Citation	Research Design, Setting, and Sample	Physical Environment Attributes	Outcome Measures of Well-Being	ICU Built Environment Impact on Outcome(s)
8. ICU Ecological Sustainability				
Abo & Nour (2017)	Case study/policy. Adult ICU. Single center; facilities.	Unit configuration; Spatial movement analysis—Saudi Arabia	Room occupancy and prefabricated modularity	Modular floor plan templates increase ecological sustainability and yield life-cycle cost benefits.
Huffling & Schenk (2014)	Case study/policy. Adult ICU. General; facilities.	Community hospitals and comparative analysis	Ecological sustainability	Staff can minimize adverse ecological health outcomes through energy conservation, waste reduction, and sustainable storage and disposal of toxic chemicals policies.
Marshall-Baker (2006)	Case study/policy. NICU. General; facilities.	Facility management	Information resource compendium and ecological sustainability	Recommended design standards for ecological sustainability including the Green Guide for Health Care, Health Care Without Harm, and Leadership in Energy and Environmental Design.
McGain & Naylor (2014)	Cross-sectional study. ICU/NICU/PICU. General; facilities.	Energy, water, transport, materials procurement, and waste management	Construction cost analysis and facility management	Ecological sustainability remains inadequately addressed in hospital planning and design. Institution-wide benchmark policies/metrics are outlined and advocated.
Paterson et al. (2014)	Cross-sectional study, ICU/ NICU/PICU. General; facilities.	Facility and Supply Chain Management	Operational and Supply Chain Management	Toolkit administrators in 6 Canadian hospitals proved effective in identifying gaps in climate change preparedness and facility resource allocation.
Quaglia et al. (2014)	Case study/policy. ICU/hospital. General; disaster victims.	Military and disaster relief housing prototypes in support of critical care medicine	Compactness, light weight, transiting, energy efficiency, and origami-inspired geometries	Modular redeployable staff housing is an effective intervention in disaster strike zones and related emergency contexts.

(continued)

Table I. (continued)

Citation	Research Design, Setting, and Sample	Physical Environment Attributes	Outcome Measures of Well-Being	ICU Built Environment Impact on Outcome(s)
Shepley et al. (2016)	Nonrandomized comparative study. NICU. Multicenter; staff and administration.	Observational assessment; materiality, equipment, water, waste management, and biophilia	Compendium of resources and organizations and ecological sustainability	Further research is advocated on the impact of NICU environments on patient, family, and staff well-being through the lens of “green” planning, design, and operational best practices.
White et al. (2013)	Policy review. NICU. General; administration and direct caregivers.	Materiality, equipment, energy conservation metrics, and biophilia	Ecological sustainability and daily operations	Recommended best practices in the planning and design of ecologically sustainable NICU built environments.
9. Recent Design Trends and Prognostications				
Brown & Gallant (2006)	Policy review/essay. Adult ICU. General; administration and direct caregiver staff.	Acuity adaptability; decentralized nurses station	Patient health status and staff performance	Acuity-adaptable rooms should be incorporated in hospital ICUs as effective in improving patient care and reducing capital expenditures.
Denham et al. (2018)	Randomized pilot study. NICU. Single center; staff and patients.	NICU, single-family room (SFR), OPBY	Patient health status and staff assessment	NICU environment is critical for short- and long-term outcomes of babies and should be designed to better support the needs of all users.
Halpern et al. (2017)	Policy review/essay. Adult ICU. Single center; patients.	ICU capsule system and room and bed monitoring	Prognostications	ICU “Biosphere Capsules” are an effective intervention. Patient care can be provided through the use of VR technology.
Hamilton (2013)	Policy review/essay. Adult ICU. General; administration, caregiver staff, patients, and families.	Planning, design, and unit operations	Patient–family satisfaction and staff performance	Argues for evidence-based design strategies for ICU environments with input from all key user constituencies/stakeholders.
Hamilton (2020)	Policy review/essay. Adult ICU. General; staff.	Tele-ICU, e-ICU, and off-site alternatives to hospital-based ICU settings	Patient health status and staff performance	Planning and design recommendations presented on ICU telemedicine as an innovative healthcare technology.

(continued)

Table 1. (continued)

Citation	Research Design, Setting, and Sample	Physical Environment Attributes	Outcome Measures of Well-Being	ICU Built Environment Impact on Outcome(s)
Harris et al. (2006)	Cross-sectional study. NICU. General; patients, family, and staff.	Multimethod, SFR, OPBY	Staff performance and patient and family well-being	SFR protocols found to yield higher patient and family privacy levels, staff satisfaction, and staff stress reduction; capital construction expenditures not notably influenced.
Huisman et al. (2012)	Policy review/essay. Hospital/ICU. General; patients, staff, and families.	Unit configuration and design: Canada and the Netherlands	Patient–family satisfaction	The use of evidence-based research in the design and construction of critical care settings can have multiple positive, long-term impacts on occupant well-being and staff performance.
Iyendo et al. (2016)	Case study/policy. Hospital/ICU. General; patients and direct caregiver staff.	Unit configuration and design attributes—Turkey and Nigeria	Patient well-being and staff performance	Artwork, daylighting, music/ambient sounds, and nature can function as positive, therapeutic distractions for patients and staff, contributing to patient healthfulness.
Kesecioglu et al. (2012)	Policy review/essay. Hospital/ICU. General; patients.	Unit configuration and design attributes—the Netherlands	Patient safety and staff performance	Occupant-centered ICUs result in higher levels of patient safety, functionality, innovations in care delivery, and adaptability in anticipation of future requirements.
Kwan (2011)	Policy review/essay. Hospital/ICU. General; patients and direct caregiver staff.	Acuity adaptability: flex-up/flex-down, universal single-stay room	Patient health status and staff performance	Acuity-adaptable patient rooms growing in acceptance; further research is needed on patient health status and staff impacts.
Ong et al. (2019)	Nonrandomized study. Adult ICU. Single center; patients and direct caregiver staff.	Unit configuration and design	Patient health status	VR can improve the quality of the ICU experience, reducing anxiety and depression without adversely impacting pain management, sleep, and delirium occurrences.

(continued)

Table I. (continued)

Citation	Research Design, Setting, and Sample	Physical Environment Attributes	Outcome Measures of Well-Being	ICU Built Environment Impact on Outcome(s)
Rashid (2011)	Case study/policy. ICU/NICU/PICU. General; university students.	Innovative technology	University-based studio design proposals	Recommended planning and design strategies for the medical ICU of the future in medical center contexts.
Rashid et al. (2014)	Cross-sectional study. Adult ICU. Multicenter; direct caregiver staff.	Unit configuration and design amenity	Staff assessment	The largest ICUs studied were rated by staff as having the most supportive, well-appointed patient rooms, adjacent circulation, and staff work zones.
Rubert et al. (2007)	Policy review/essay. Adult ICU. General; staff, patients, and families.	Unit configuration and design	Environmental stress	Stress-reducing design attributes (nature, air quality, family engagement, art, music, and aromatherapy) were found to improve the hospitalization experience for patients and families.
Rybkowski et al. (2012)	Policy review. NICU. General; planning/design team.	Unit configuration and design attributes	Patient health status and staff assessment	Target value design is an effective method in comparatively weighing the merits and cost implications of NICU semi-open versus private patient room configurations.
Sessler (2014)	Policy review/essay. Adult ICU. General; patients, staff, and administration.	Patient room design and robotics	Patient health status and staff performance	“Smart” ICU environments can contribute to greater patient safety, satisfaction, higher family satisfaction, and direct caregiver performance.

(continued)

Table 1. (continued)

Citation	Research Design, Setting, and Sample	Physical Environment Attributes	Outcome Measures of Well-Being	ICU Built Environment Impact on Outcome(s)
Stevens et al. (2010)	Nonrandomized study. ICU/NICU. Multicenter; staff and patients.	Unit configuration and design amenity	Patient safety, health status, and staff assessment	Staff assessments were found to be significantly higher in private rooms compared to OPBY conditions in a NICU setting.
Stichler (2012)	Policy review/essay. NICU. General; patients, families, and staff.	Private patient–family rooms	Patient and family well-being	SFR demonstrated as an effective evidence-based design strategy in renovated as well as newly constructed NICU facilities.
Sundberg et al. (2017)	Case study/nonrandomized. Adult ICU. Single center; staff.	Unit configuration and design amenity—Sweden	Acoustics, views of nature, and staff assessment	A redesigned ICU patient care room resulted in increased staff well-being and staff performance.
Thompson et al. (2012)	Policy review/essay. ICU/NICU/PICU. General; administration and unit staff.	Archival data—American College of Critical Care Medicine	Organizational behavioral management	The design quality of critical care facilities has a direct impact on organizational performance, clinical outcomes, and the cost of healthcare.
Valentin & Ferdinande (2011)	Case study/policy. Adult ICU. Single center; patients and staff.	Unit configuration and design amenity—Austria	Patient safety, well-being, and staff assessment	ESICM was demonstrated to be an effective strategy in the ICU planning and design process.
Zborowsky & Hellmich (2011)	Policy review/essay. ICU/hospital. General; facility design professionals.	Critical care built environment	Health promotion and well-being	Healthcare facility planning and design professionals need to become more adept at incorporating evidence-based critical care design research best practices.

Note. ICU = intensive care unit; NICU = neonatal ICU; PICU = pediatric ICU; MRSA = methicillin-resistant *Staphylococcus aureus*.

outcomes. Interventions primarily focused on the use of live plants, access to outdoor therapy gardens, and exposure to outdoor nature views (Table 1).

Plants and Gardens

Plants and gardens are often employed in hospitals to facilitate nature engagement within the healthcare environment. Patients exposed to either plants or images of plants in hospital waiting rooms report greater stress reduction as compared to controls (Beukeboom et al., 2012). Similarly, subjects presented with photos of hospital rooms containing plants report less stress compared to those shown photos of rooms without plants (Tanja-Dijkstra et al., 2008). Visiting an outdoor garden can reduce sadness and stress scores in families of hospitalized patients (R. S. Ulrich et al., 2020). Nursing staff have reported less burnout, feelings of depersonalization, and emotional exhaustion after taking breaks in outdoor gardens (Cordoza et al., 2018). These studies demonstrate that live plants and hospital gardens are likely of therapeutic benefit to patients, staff, and families.

Nature Views

Windows and nature views are interventions to promote positive distraction and stress reduction in the ICU. Surgical ICU patients admitted to rooms with nature views experience a slightly shorter ICU length of stay compared to those in rooms with views containing industrial informational content, although notably, there is no difference in hospital and ICU mortality, ICU readmission rate, or delirium occurrences (Kohn et al., 2013). Similarly, patients with acute brain injury admitted to windowed ICU patient rooms demonstrate no difference in functional status, ICU–hospital length of stay, or mortality compared to those admitted to windowless rooms (Wunsch et al., 2011). The effect of nature views in the intensive care environment on hospital staff has also been examined. A single-center study evaluating outcomes after moving to a new ICU with more windows and nature views showed a statistically significant decrease in staff

absenteeism and employment vacancy rates (Shepley et al., 2012). Pati and colleagues (2008) also evaluated exterior nature views experienced by nursing staff, reporting improved alertness levels and a decrease in stress. These studies suggest that while nature-content views per se are not associated with traditional ICU patient outcomes measures, they likely contribute to an improved work environment for healthcare providers.

Family Accommodations in the ICU Environment

Familial presence within the ICU environment is increasingly recognized as a vital component of the care of critically ill patients. In a qualitative study examining the experiences of families of children hospitalized in a PICU, MacDonald and colleagues (2012) described a frequent disconnect between family-centered medicine and the modern medical practice of intensive care. They described this conceptually as a conflict between the need for the ICU room to serve as the sick child’s “bedroom” as well as a workplace for healthcare professionals, and noise, privacy policies, and visitation restrictions may affect families and healthcare providers in opposite ways. The principle of a “healing environment of care” can be utilized to facilitate the engagement of families in the ICU by both promoting a therapeutic relationship between patients, caregivers, and families as well as highlighting environmental design strategies to support healing (Rashid, 2010). Guidelines for family support in the ICU environment have suggested that single rooms should be utilized to improve patient privacy and should include dedicated family space (Davidson et al., 2007). It has also been suggested that graphics and wayfinding systems be implemented and waiting rooms be placed close in proximity to patient rooms (Davidson et al., 2007). Updated guidelines have reinforced the importance of providing single-bed rooms and noise reduction strategies as well as sleep surfaces for families as environmental design interventions to facilitate family integration and suggest a checklist to assess ICU readiness for family-centered care (Davidson et al., 2017). However, the authors

also acknowledge the paucity of research on how the physical setting can optimally improve family engagement in the ICU. Review of the recent literature revealed 12 studies describing various environmental design interventions in support although there have been no randomized trials, to date. These measures have focused on improving family and patient privacy, including designation of “family” corridors adjacent to or within the ICU (Table 1).

Dedicated Family Spaces

Dedicated family space at bedside is associated with an increased proportion of visitors at night (Hunyh et al., 2020). Family-initiated conversations with healthcare providers are higher in ICUs that utilize a shared provider–family hallway space as opposed to units with separate hallways for healthcare staff and families (Rippin et al., 2015). Critical care units that employ noise-reduced, single-bed patient rooms that incorporate daylight and dedicated washroom facilities for families have been associated with higher family satisfaction scores (Jongerden et al., 2013). For families of patients admitted to a neurotrauma ICU, physical environment attributes that correlated with family satisfaction included noise level, size of the waiting room, private spaces, and washroom facilities (Peterson et al., 2020). Structured interviews with nurses of dying patients in the ICU have highlighted that families commonly desire spaces allowing both privacy and togetherness and connection with other family members (Fridh et al., 2009). In a multisite family satisfaction survey evaluating family sleep location, the caregivers of children admitted to PICUs were most likely to report sleeping in the child’s room, followed by their own home and then a shared family accommodation program (Franck et al., 2015). However, other studies demonstrate a substantial proportion of family members reporting sleep disturbance and poor sleep quality in ICU waiting rooms, suggesting that hospital accommodations are inadequate for quality sleep (Day et al., 2013; Stremler et al., 2014). These studies suggest that design interventions such as single-bed rooms, dedicated family space, family

sleep accommodations, and common areas for interaction with staff may help improve family engagement at bedside in support of the critically ill.

ICU Spatial Configuration and Amenity

Despite extensive research regarding ICU configuration and ergonomics, performance obstacles related to the physical environment continue to be frequently identified by nurses, such as room disorganization, noisy and crowded workspaces, and insufficient areas dedicated to medical documentation (Gurses & Carayon, 2009). The review team found 22 articles, with 10 nonrandomized comparative studies, nine cross-sectional studies, two opinion essays, and one systematic review. Interventions have focused on single versus multi-bed room modules, nursing station typology, visibility patterns in the ICU, and workplace performance obstacles (Table 1).

Nurse Station Design and ICU Layout

In a review of adult ICU design in the United States, Catrambone and colleagues (2009) identified four predominant unit configurations, with a “U-shaped design” being most common, followed by “spokes/no end station,” “parallel corridor,” and “surrounded” configuration. Spatial configurations are often classified as centralized, decentralized, and hybrid based upon nursing station type. Unit layout affects interactions and communication patterns between healthcare providers, with a reported lower frequency of physician–nurse communications and social interactions in decentralized ICUs (Zborowsky & Hellmich, 2011). Layout design, visibility patterns, and accessibility were identified in a systematic review of healthcare physical design attributes that impact teamwork and communication (Gharaveis et al., 2018). In consideration of the general hospital built environment, decentralized nursing stations have been associated with improved documentation practices, less steps taken, decreased energy expenditure by healthcare providers, and better utilization of medication and supply rooms; however, they

have also been associated with a decrease in nurse-to-nurse collaborations and teamwork (Copeland & Chambers, 2017; Pati et al., 2015; Real et al., 2016). In a systematic review evaluating decentralized nursing station design, there was a notable decline in nursing teamwork in the decentralized models (Fay et al., 2019), highlighting systems-level challenges posed by the introduction of the decentralized unit (Real et al., 2016). In a theoretical essay, Hamilton and colleagues (2018) indicated that concerns regarding travel distance and visibility challenges in the decentralized unit may be related to corridor design and overall size of the ICU. Systematic field observations have also demonstrated an association between spatial design and healthcare worker interaction-related behaviors in adult ICUs (Rashid et al., 2014). In this study, interactions that occurred while sitting tended to occur in areas that facilitated environmental awareness and visibility.

As a method to better understand the complex interaction between ICU spatial configuration, healthcare provider interactions, and communication patterns, Cai and colleagues proposed a system of spatial measures to better evaluate nursing station typology (Cai & Zimring, 2012). In this approach, integration, team distance, and peer distance were utilized as spatial metrics to understand unit layouts, demonstrating a strong correlation with nurses' physical location, awareness of colleagues, and interactions with other providers. This suggests it may be useful to consider team distance and peer distance in addition to patient visibility patterns when evaluating nursing station and ICU spatial configuration.

Visibility remains an important component of ICU design with implications for both healthcare provider workflow and patient outcomes. Physicians and nurses often differ in preferred workflow locations, with nurses proportionally favoring areas with higher targeted visibility toward patient beds and physicians favoring areas with generic visual connectivity and large open spaces (Lu & Zimring, 2011). In a single-center study evaluating the PICU environment, O'Hara and colleagues (2018) concluded that maximization of visibility through the design of corner work zones can enhance team interactions and

patient observation, creating opportunities for macrocognition and cognitive adaptation to complex situations. For severely ill patients admitted to the ICU, one study found a significantly higher hospital mortality rate in patients admitted to rooms with low visibility from the central nursing station (Leaf et al., 2010). Lu and colleagues (2014) further evaluated visibility patterns and demonstrated that both the field of view of the patient's head and the room's distance from the nursing station accounted for differences in mortality. Patient visibility can also be improved through the design of wider corridors; fewer small, convex spaces; and shorter travel distances (Hadi & Zimring, 2016).

Single and Multibed Rooms in Intensive Care

The adoption of the all single-bed ICU unit has provided an opportunity to evaluate corresponding patient, staff, and family outcomes. Numerous studies have reported higher family satisfaction scores in single-bed ICU rooms as compared to multibed rooms and often cite enhanced privacy as a key driver of this association (Apple, 2014; de Matos et al., 2020; Stevens et al., 2012). Hospital staff have also reported improved quality of the work environment and enhanced patient safety in single-bed rooms (Bosch et al., 2012; Stevens et al., 2012). Conversely, single-bed rooms have been associated with higher staff stress (de Matos et al., 2020), increased travel distances, steps per nursing shift (Stevens et al., 2012), and feelings of staff isolation and difficulty with obtaining assistance from colleagues (Apple, 2014). Hybrid room designs consisting of two single-patient rooms connected by a shared space for documentation and monitoring have been proposed as a solution to the competing interests between single and multibed rooms. Hospital staff working in hybrid ICU room configurations report efficient patient observation, enhanced collaboration between healthcare workers, and improved patient privacy as compared to multibed rooms (Apple, 2014).

The prevention of ICU-associated delirium has gained increased focus due to its association with length of stay, patient morbidity, and mortality, with room configuration emerging as a

modifiable environmental risk factor. Adult patients admitted to multibed ICU rooms are four times more likely to develop delirium compared to those admitted to single-patient rooms (Caruso et al., 2014). Age also appears to be an important factor in understanding the relationship between ICU room configuration and delirium. Arenson and colleagues showed that there was no difference in delirium prevalence between single- and multibed rooms for those greater than 65 years of age; however, patients less than 65 years of age demonstrated a greater proportion of delirium days when admitted to multibed ICU rooms compared to single-bed rooms (Arenson et al., 2013).

Noise Considerations in ICU Environments

Various organizations have proposed noise-level guidelines for the hospital setting. The World Health Organization has recommended hospital noise levels not exceed 35 decibels during the day and 30 decibels at night, with nighttime noise peaks less than 40 decibels (Berglund et al., 1999). The American Academy of Pediatrics (1997) has recommended noise levels not exceed 45 decibels in the NICU setting. There have been 15 recent studies published regarding noise levels in the ICU environments ($n = 5$ NICU, $n = 4$ PICU, $n = 6$ adult ICU). Published studies focus on the themes of measured ambient noise in the ICU versus common noise sources, the effect of ambient noise on patients and staff, and design-based mitigation strategies (Table 1).

Noise Levels and Stress

Measured ambient noise often exceeds recommended levels in adult ICUs (Christensen, 2007; Macedo et al., 2009; Ryherd et al., 2008), PICUs (Carvalho et al., 2005; Kawai et al., 2019), and NICUs (H. L. Chen et al., 2009; Lasky & Williams, 2009), with average noise levels ranging from 48 to 70 decibels and maximum levels ranging from 67 to 120 decibels. Temporal studies of ambient noise demonstrate higher levels during morning shifts compared to evening/night

shifts (Carvalho et al., 2005; Kawai et al., 2019; Matook et al., 2010) and during weekdays, compared to weekends (Christensen, 2007). Noise levels also increase over time in the NICU setting and appear to be attributable to age-related changes in bed type and respiratory support equipment needs (Lasky & Williams, 2009). Common sources of ambient noise include equipment such as monitors and alarms, hospital staff conversations at nurses stations, and handovers between ICU and operating room teams at bedside (Carvalho et al., 2005). Careful consideration of noise pollution must occur when introducing new equipment and technologies, as evidenced by a report describing a marked increase in noise levels after the addition of motion-sensing motorized paper towel dispensers and a new audio communication system (Brandon, et al., 2007). Postdischarge surveys demonstrate that patients often recall various ICU noises and sounds (Johansson et al., 2012). Healthcare workers in the ICU environment also report that elevated noise levels contribute to feelings of fatigue, difficulty concentrating, and tension headaches (Ryherd et al., 2008).

Design Interventions to Decrease Noise

Multiple environmental interventions have been evaluated as potential modifiers of ambient noise. Some studies have reported that single-bed ICU rooms have lower sound levels compared to multibed rooms (H. L. Chen et al., 2009; Kol et al., 2015), although others have shown no difference (Kramer et al., 2016). Wang and colleagues (2013) reported a decrease in average and maximum noise levels in patient care areas after the addition of a dedicated service corridor. Architectural features such as soundproof headwalls to separate patients from medical equipment and an anteroom between the patient room and corridor result in reduced average and maximum sound levels in ICU rooms (Leutz et al., 2016). A multiphase quality improvement initiative in a NICU demonstrated that lowering equipment alarm sounds was associated with an overall reduction in noise levels (Chawla et al., 2017).

Artificial and Natural Lighting in ICU Environments

Hospital building codes emphasize that lighting should be tailored to facilitate the diverse needs of healthcare staff, with a recommended level of 30 lux for circulation areas, 300 lux for observation and medical documentation areas, and between 3,000 and 10,000 lux in critical examination and procedural areas (Shepley et al., 2012). The American Academy of Pediatrics (2002) has recommended a maximum light level of 646 lux in NICU environments. Measured light levels in the ICU often fall within guideline recommendations (Lasky & Williams, 2009). A total of 10 recently published studies on lighting in the ICU were identified ($n = 5$ NICU, $n = 5$ adult ICU), focusing on ambient lighting levels, light sources, light-mitigating interventions, and patient outcomes (Table 1).

Light Interventions in the ICU Environment

Light source and level of illumination are frequently identified as modifiable variables. Infants exposed to lower minimum and maximum illumination levels in the NICU experience less periodic breathing and awake time (Stevens et al., 2007). An NICU-cycled light strategy throughout the day versus continuous bright light, or near darkness, resulted in shortened hospital length of stay in premature neonates (Morag & Ohlsson, 2015). Subtle variations in ambient light levels have also been associated with increased awakening in premature neonates, suggesting that design interventions to modify abrupt changes in lighting may affect NICU outcomes (Zores et al., 2018). In a systematic review, it was concluded that changes in light level should be gradual, light mitigation protection should be used for infants less than 32 weeks corrected gestational age, and premature infants should not be exposed continuously to high light levels (Zores-Koenig et al., 2020).

Light exposure has been studied as a modifiable intervention. Rompaey and colleagues (2009) evaluated ICU environmental risk factors and demonstrated a lack of natural light as a risk factor for delirium. The technique of dynamic

light therapy involves periodic variation of ambient light levels in indoor environments and has been suggested as an intervention to decrease the incidence of ICU delirium. However, a recent randomized control trial evaluating the effect of dynamic light application on the incidence of delirium was concluded early due to futility and lack of improved outcomes (Simons et al., 2016). Adult ICU patients admitted to rooms with natural daylight experience slightly shorter length of stays compared to those with primarily artificial light sources, although notably, there appears to be no difference in hospital and ICU mortality, ICU readmission rate, delirium, sedative use, and analgesic requirement (Kohn et al., 2013; Verceles et al., 2013). Together, these data suggest further research is needed to better understand targeted patient populations and outcomes in the use of light as a therapeutic modality.

ICU Patient Safety and Infection Control

Hospital built environments have been modified to decrease medical errors and improve patient safety and infection control. Design interventions employed include minimizing ambient noise, judicious use of lighting to facilitate task completion, and single-bed patient rooms. The review team identified 11 studies evaluating these types of environmental design interventions (Table 1).

ICU Environment Infection Control Measures

Single-bed ICU rooms have been investigated as a design intervention to decrease nosocomial infections. In a single-site study, Levin and colleagues (2011) demonstrated that adult patients admitted to a single-bed room acquired fewer antibiotic-resistant infections during their stay. Bracco et al. (2007) demonstrated that patients admitted to single-bed rooms had lower relative risk of acquisition of methicillin-resistant *Staphylococcus aureus* (MRSA), *Pseudomonas aeruginosa*, and *Candida* spp. compared to those in multibed rooms. Bloemendaal and colleagues (2009) also reported less acquisition of MRSA

in single-bed rooms. Similarly, Teltsch and colleagues (2011) demonstrated that conversion from multibed to single-bed ICU rooms was associated with a lower nosocomial infection rate compared to a control multibed unit. However, moving adult ICU patients with documented MRSA to isolation rooms or cohorted multibed rooms does not significantly reduce cross-infection rates (Cepeda et al., 2005). Stiller and colleagues collected data on structural design elements in German ICUs to examine hospital architecture in the context of nosocomial infection occurrences. The findings demonstrated only minor associations between architectural design factors and ICU-based infection, suggesting that design features were subordinate to more primary drivers of infection control (Stiller et al., 2017). Additional design interventions, such as the introduction of a whole-room atomization system for use in conjunction with standard cleaning practices, have been demonstrated to decrease bacterial counts *in vitro* (Reynolds et al., 2020).

Adverse Outcomes and Patient Safety

Healthcare environmental design has been utilized to promote patient safety. Lighting, nature and nature representations, and virtual reality (VR) interventions have correlated with improved pain management (Malenbaum et al., 2008). For severely ill patients admitted to the ICU, a significantly higher mortality rate occurred for those admitted to rooms with low visibility from the central nursing station compared to rooms with higher visibility (Leaf et al., 2010). However, admission to a room with high visibility was not associated with an improved outcome for trauma patients (Pettit et al., 2014), indicating that visibility is but one factor in understanding the complexities of ICU patient safety. New frameworks to facilitate incorporating human factors and ergonomic principles into systems engineering models for improved patient safety often incorporate elements of the physical environment (Carayon et al., 2020), thus underscoring the need for continued research to better understand this dimension of ICU hospitalization.

Portable Field Hospitals and Disaster Mitigation Including COVID-19

The rapid proliferation of the deadly coronavirus in 2020 prompted healthcare provider organizations globally to confront a major public health crisis and reassess their in-house facility infrastructure (Auerbach et al., 2020; S. Chen et al., 2020; Z. Chen et al., 2020; Keenan, 2020). COVID-19 precipitated innovative responses in ICU built environments, and in telemedicine, in particular. Wosik et al. (2020) examined telemedicine applications in numerous hospitals in the context of the pandemic, specifically, ICU patient respiratory functions, and space requirements for ventilator equipment (Doshi et al., 2020). Fortis et al. (2014) demonstrated that telemedicine, effectively implemented, can reduce healthcare costs while improving patient outcomes, enabling patients to be cared for vis-à-vis virtual bedside consultation (Table 1).

Rapid Responsiveness

In France, direct care provider involvement is urged from the earliest facility planning stages to operationalization and staffing (des Déserts et al., 2020). In Wuhan, China, two 10,000-bed Fangcang shelter hospitals were constructed in March 2020 (S. Chen et al., 2020; Z. Chen et al., 2020; Owens et al., 2005); building information modeling (BIM) technology and modular composite building finished products were utilized to design and construct the modular Wuhan Leishenshan Hospital in 2 weeks. All interior floors, exterior walls, and heating, ventilation, and air-conditioning (HVAC) systems were designed using BIM (L. Chen et al., 2021). Best practices in biocontainment unit facility planning and design have been developed (Flinn et al., 2020; Lenaghan & Schwedhelm, 2015). These facilities are reliant on preexisting technological infrastructure, that is, site utilities, access to transport routes to maintain supply chain continuity, telecommunications support, and availability of installation sites ranging from community centers to sports stadiums and to open fields (Fang et al., 2020). Field hospital installations must be quickly

constructible, cost-effective, and reduce capacity pressures on nearby conventional medical facilities (Keenan, 2020; Louri et al., 2020; Pucher et al., 2014; Zhou et al., 2020). The Fangcang shelter hospitals had the advantage of constructability on immediately available land parcels. As noted by both Kreiss et al. (2010) and Burnweit & Stylianos (2011), traditional medical technologies must be adaptable to emergency field hospital environments, specifically, negative air filtration HVAC system design (Santos et al., 2020). Ten strategies were recently outlined to guide the design and operations of resilient hospital environments (Capolongo et al., 2020). During the COVID-19 pandemic, a regional hospital in Italy was repurposed for cardiovascular emergencies. This new role required an increase in ICU bed capacity and support spaces (Zangrillo et al., 2020). In the United States, the MED-1 mobile vehicular field hospital, first deployed in the aftermath of Hurricane Katrina in New Orleans in 2005, has proven adaptable in diverse site installation contexts (Blackwell & Bosse, 2007; Burnweit & Stylianos, 2011). Vehicular-based and modular surge field hospitals must house advanced equipment allowing for rapid reconfiguration in the field as needs evolve (Lee et al., 2019). A recent review was conducted of nine COVID-19-inspired hospital prototypes put forth by international architectural firms. The major findings include individualized patient treatment modules, dedicated service corridors, and negative air pressurization filtration systems (Sonmez, 2020).

Intensive care must be adaptable to on-site determinants in humanitarian disaster relief contexts (Blackwell & Bosse, 2007; Lee et al., 2019). Organizational effectiveness, appropriate technical support, and staff intercommunication are of paramount importance in effective facility operations (Lee et al., 2019). First response pediatric care, including NICUs, should be available in postdisaster contexts (Burnweit & Stylianos, 2011). The provision of triage assessment is of utmost priority (Kreiss et al., 2010). Cross-cultural differences between patients, caregivers, and families must be accounted for in the delivery of healthcare in unfamiliar postdisaster strike zones (Owens et al., 2005). The ethical integration

of ethical, humanitarian principles in critical care emergency response contexts preserves human dignity (Lee et al., 2019).

ICU Ecological Sustainability

Sustainability and Efficiency

The day-to-day operations of hospital ICUs contribute to the depletion of the earth's natural resources (McGain & Naylor, 2014). The Green Guide for Health Care program articulated planning and architectural design criteria for sustainable best practices in hospital design, construction, operation, and maintenance (Marshall-Baker, 2006). Ecologically based energy efficiency is increasingly a baseline minimum criterion essential to achieving longer term facility operational efficiency. An ICU's physical layout impacts energy consumption; single-bed rooms in hospitals have been linked with reduced infection rates but can contribute to higher overall energy consumption levels (Huffling & Schenk, 2014). Trades-offs are necessary to balance higher initial construction costs with reduced recurring, life-cycle operational expenses. Further research is needed on this issue including the impacts of floor template size, configuration, and the use of energy-star-rated equipment (McGain, 2014).

Flexible space has been demonstrated as the key in achieving ecologically efficient ICU built environments. Flexible space includes spatial buffer zones, efficient internal circulation (without sacrificing spaciousness), variable ceiling heights and configurations, phased campus design and construction, and the sensitive integration of buildings into their environmental contexts (Paterson et al., 2014). ICUs can benefit in this regard from multifunctionality, that is, acuity-adaptable patient rooms, equipment, and interior amenities. Ecological efficiency in ICUs is attainable by means of standardization and modularity without compromising flexibility and adaptability (Abo & Nour, 2017). Ecological design variables include the structural system, cladding type, window/wall system, window-to-wall area ratio, number of treatment bays, and bay width (Valentin, A., & Ferdinande, P, 2011). Innovative geometries have been

studied in the design of ecologically efficient specialized care units. Recent origami-inspired critical care structures with thermally insulated rigid walls include the Level Shelter Module, a system featuring polymorphic shape optimization in the attainment of life-cycle energy efficiencies (Quaglia et al., 2014).

Reduction of Carbon Emissions and Biohazardous Waste

ICU environments require highly energy-intensive equipment that produces significant toxins and as such can pose a threat to the well-being of building occupants (Huffling & Schenk, 2014). McGain et al. (2014) selectively studied hospital occupants' energy consumption patterns: water consumption, materials procurement, toxic waste generation, and closely related in-unit behaviors. Larger scale systems including cogeneration, solar thermal, and ground-sourced heat pumps have also been studied recently. Research is needed to further understand the behaviors, attitudes, and organizational culture imperatives, that is, staff dismissiveness, within ICUs to further increase ecological sustainability quotients, with increased collaboration between key stakeholders, including clinicians, engineers, architects, and equipment specialists (McGain, 2014). Nursing staff are encouraged to advocate for energy-star-rated equipment, programmable diagnostic and monitoring equipment, and window screens blocking solar gain during the day and operable at night. ICU staff should routinely recycle–reuse equipment thereby reducing overall material consumption, participate in “green teams,” and initiate commuter carpools and community outreach programs to minimize the hospital's ecological footprint (Huffling, 2014).

The sustainable design movement, to date, has had relatively little direct influence on hospital intensive care built environments. Finish wall, flooring, and ceiling materials are often problematic insofar as they possess substances that can emit toxins into the ambient room environment. In response, recent data suggest these finish surface materials are specified to be nontoxic, including all ceilings, waste management, water-efficient fixtures, wall and floor surfaces, and furnishings that

are easily cleanable. Off-gassing of materials remains a persistent concern due to the potential deleterious impact of airborne toxins, with particular attention accorded infant incubators (Marshall-Baker, 2006; Shepley, 2016). Smart lighting systems produce full-spectrum lighting—a health-promoting alternative to conventional fluorescent fixtures, combined with natural daylighting and person–nature biophilic affordances. Standards currently exist for sustainable NICU design and construction, that is, floor plan layouts, materials of construction, and equipment and furnishings (White et al., 2013). These resources include Health Care Without Harm, Envirofacts Master Chemical Integrator, Leadership in Energy and Environmental Design, The Green Guide for Healthcare, and the sixth edition of the Recommended Standards for NICUs (Marshall-Baker, 2006).

Recent Design Trends and Prognostications

ICU–NICU Spatial Configuration (Circulation, Flow, Size, and Amenity)

A distinct shift is underway from mixed-specialty to single-specialty ICUs featuring innovative “racetrack” circulation typologies (Rashid, 2014). Such wraparound circulation pathways help to avoid bottlenecks, undue congestion, and promote wayfinding. In addition, along with efficiently configured circulation, patient room numbers should be clearly marked, with systematic directional signage. Currently, same-handed, single rooms are increasingly preferred versus larger, multibed rooms (Table 1). The rationale is patient safety, although concern persists with regard to fitting medical equipment into these reduced-in-size spaces. In addition, discrete yet layered multiple zones are advocated, consisting of patient room, family support, unit-wide support, and clinical support zones (Thompson et al., 2012). Sundberg et al. (2017) concluded that the involvement of critical care nursing staff in the design of evidence-based ICU environments has a direct impact on subsequent staff well-being and caregiving behaviors. This was found through interviews with critical care nurses

combined with qualitative analysis (Sundberg et al., 2017).

NICUs are shifting toward single-family rooms (SFRs) but for slightly different reasons: to facilitate families' greater engagement, improve infection control, and minimize exposure to adverse environmental stimuli (Denham et al., 2018). Infant maternal bonding, noise mitigation, improved staff satisfaction and morale, family zones, privacy, adequate space for routine activities on the part of staff and families alike, and staff-family communications are of high priority (Harris et al., 2006; Stevens et al., 2010). From the perspective of staff direct caregivers, excessive noise and poor illumination are persistent hindrances in ICU built environments (Stevens et al., 2010). The utilization of VR technology in the planning and design process has been demonstrated to improve the ICU experience (Ong et al., 2019). Also, the use of "meditative VR" has been shown to reduce anxiety and depression among patients, although it has not yet been linked with significantly improved sleep or pain management outcomes (Harris et al., 2006). The ability of patients and families to self-regulate lighting and temperature levels has been empirically linked with improved well-being and satisfaction (Thompson et al., 2012).

Zborowsky & Hellmich (2011) discussed the importance for healthcare design professionals to better understand the needs and preferences of patients, families, and staff and that this goal is best achievable by means of data transparency and reliance on the synthesis of qualitative as well as quantifiable health status outcomes. Nurses, ideally, can function as lead standard-bearers in this evidence-based research effort as they are most directly immersed, daily, and as such can inform design professionals in understanding patient safety and infection control measures, quality improvement, and the key support role of the built environment regarding occupant satisfaction and well-being (Zborowsky, 2011). Valentin & Ferdinande (2011) discussed an environmental assessment tool (ESICM) that seeks to capture functional criteria in construction. This tool records on an ICU room-by-room basis daily and hourly activity-occupant needs criteria and recommends feasible spatial configuration

templates, equipment requirements, life safety criteria, and central hospital support interdependencies. Kesecioglu et al. (2012) examined the recent literature on ICU design in relation to patient-centered care, unit functionality, infection control, building-related life safety issues, and "futureproofing."

Halpern et al. (2017) examined the efficacy of the Biosphere Capsule in capturing the essential aspects of an ICU through the application of VR headsets as a means to improve user participation. Hamilton (2020) discussed in detail the future of the ICU in terms of its spatial configuration, equipment, furnishings, the therapeutic function of natural daylight, and increasing role of tele-ICU and e-ICU protocols in improving the design support provided by the built environment. Using an architectural university design studio as a laboratory, Rashid (2014a), Rashid et al (2014b) examined innovative medical and building technologies, and Sessler (2014) examined the potential role of Smart ICU built environments in improving unit functionality, patient health status, and staff performance.

Acuity Adaptability

The acuity-adaptable room unit model and its manifestations in hospital intensive care have been the subject of increasing research attention. This concept can yield enhanced individualized zones for patients, families, and staff and is adaptable to ever-evolving technological innovation (K. K. Brown & Gallant, 2006). Its core variants—flex-up, flex-down, universal room, and single-stay units—in addition to the core original acuity-adaptable patient room template first introduced in the 1990s, are predicted to be more widely incorporated in ICUs in the coming years (Kwan, 2011).

Single Family Versus Semiprivate Rooms

Many NICUs in North America are being transformed from small-scale open wards to single rooms. Rybkowski et al. (2012) presented a set of facility planning principles defined as Target Value Design for application in the transition from all semiprivate (open bay) to SFR NICUs. In addition, the SFR model and its ramifications

for patient, nursing, and family satisfaction with the physical setting are described as a recent evidence-based, applied strategy for renovating existing and constructing new ICUs. It is predicted that the SFR model will become more widely advocated by clients and their commissioned design teams (Stichler, 2012).

Holistic Strategies

Hamilton (2013) has argued for further application of evidence-based design in the medical intensive care milieu, as this will improve the quality of care for patients, families, and yield more supportive work conditions for direct caregivers. Huisman et al. (2012) examined the physical environment's fundamental, timeless effects on health status outcomes. This is achievable through systematic assessment of occupant well-being, that is, the experience of patients, family, and staff together with systematic, iterative assessment of technical support systems including materiality, space planning attributes, interior amenities, and relationship to central hospital support services. Therapeutic design interventions in critical care units have been shown to provide positive distractions for patients and their direct caregivers. Artwork, natural and artificial lighting, views to the exterior environment and landscape, access to gardens, noise minimization on the unit, ambient music and soundscapes, therapeutic color palettes, maximizing one's sense of personal control and privacy, the provision of social supports, healthful air quality, cleanliness, and maintenance collectively contribute to a positive hospitalization experience (Iyendo et al., 2016). In short, a reduction in physical setting—emanating environmental stressors in the ICU can mitigate adverse outcomes (Rubert et al., 2007).

Summary and Conclusions

In 2004, R. S. Ulrich, et al. concluded that evidence-based research and design had by then demonstrated meaningful engagement with nature and landscape is preferred during hospitalization. Staff, family, and patient-centric built environment amenities have positive impacts on satisfaction, with a role in decreasing patients'

pain. Their investigation, however, did not include the 2003 SARS pandemic nor general pandemic considerations in planning and designing ICU built environments—because scant evidence-based research existed on that subject at the time. Since then, pandemic concerns in the ICU milieu have dramatically risen in importance in conventional hospitals, adjunctive surge capacity isolation settings, and in postdisaster portable field hospital contexts.

The ICU multiuser environment, as a workplace for ICU professionals, a place of care for patients, and a place for connection with patient families and other loved ones, is of enduring, central importance. This comprehensive review has underscored the therapeutic importance of nature and outdoor views, the deleterious impact of noise as a stress source, the increasingly important interventional role of families, the acceptance of the all-private-room ICU, and the continued call for evidence-based research on reducing medical errors and concomitantly increasing patient safety and infection control. Also underscored is the role of ecological sustainability in design, construction, and daily operations—and climate change—related disaster-responsive and pandemic architecture for health in support of public health crises (Verderber, 2021). As for the plight of direct caregivers, the COVID-19 pandemic has been difficult for frontline nurses and others who witnessed firsthand such widespread suffering and death (T. Brown, 2021).

The ICU multiuser environment, as a workplace for ICU professionals, a place of care for patients, and a place for connection with patient families and other loved ones, is of enduring, central importance.

In Table 2, a summary of the findings of this comprehensive review of the literature is presented. The 135 source citations are categorized in two groupings: quantitative investigations and qualitative investigations/essays. Within each type, findings or assertions of positive outcome, no effect, or a negative outcome are denoted. This overview can serve as a basis for identifying areas warranting further research. Research content

Table 2. ICU Built Environment Literature (2005–2020): Quantitative Investigations/Essays, and Associated Outcomes.

Design Intervention	Single-Bed Rooms	Plants/Gardens	Nature Views/Art	Dedicated Family Space	Decentralized Nursing Station	Unit Configuration	Visibility	Natural Light	Acuity-Adaptable Rooms	Virtual Reality Technology	Telemedicine Capability	Portable Hospital	Field Hospital	Participatory Design
Number of studies ^a	16 ^b (6) ^c	4	5 (3)	5	6	4 (20)	2	3 (2)	1 (3)	3 (3)	1 (6)	(14)	(14)	(9)
Patient outcomes														
Stress reduction	(++)	++	(+)			(+)				+(++)				
Shorter ICU LOS			+			(+)		+					(+)	
Reduced ICU mortality			00			(++++)	++0	0(+)					(+++++)	
Decreased delirium	++		0(+)					+0		(+)				
Decreased ambient noise	+0					+(+)							(+)	
Decreased infections	++++00(+)					(++)			(+)				(++++)	
Decreased pain			+					+0		+(+)	(+)			
Improved patient safety	+(++)					(++)			(+)	(+)	(++++)		(+++++)	(++)
Family outcomes														
Reduced family stress	(+)	+												
Facilitate family engagement	+			+										(+)
Improved family satisfaction	+++((+)+			++++		(+)								
Improved communication					+									

(continued)

Table 2. (continued)

Design Intervention	Single-Bed Rooms	Plants/ Gardens	Nature Views and Art	Dedicated Family Space	Decentralized Nursing Station	Unit Configuration	Visibility	Natural Light	Acuity-Adaptable Rooms	Virtual Reality Technology	Telemedicine Capability	Portable Hospital	Field Hospital	Participatory Design
Number of studies ^a	16 ^b (6) ^c	4	5 (3)	5	6	4 (20)	2	3 (2)	1 (3)	3 (3)	1 (6)	(14)	(14)	(9)
Staff outcomes														
Stress reduction	-(+)		+			(+)						(++)	(++)	(+)
Decreased staff burnout		+				-(+)					(+)	(++)	(++)	
Improved staff efficiency	(+)		+(+)		+	-(++++)		(+)						(+)
Improved collaboration	-				-----	(++)+			(+)		(+)			(+++)
Systems outcomes														
Reduced energy consumption	-		(+)			(+++)						(+)	(+)	(+)
Reduced healthcare costs						(+)			(+)		+			
Design criteria			(+)			(+++++)			(+)		(+)	(++)	(++)	(+++++)

Note. ICU = intensive care unit; LOS = length of stay; quantitative investigation: + beneficial effect observed on the studied outcome; 0 neither beneficial nor harmful effect as there is no effect on the study sample is too small; - negative effect observed on the studied outcome; qualitative investigation/essay: (+) beneficial effect observed on the studied outcome; (-) negative effect observed on the studied outcome.

^aSome literature sources are cited in more than one column. ^bQuantitative investigation. ^cQualitative investigation/essay.

gaps in this literature became apparent, notably the need to conduct more in-depth research on the physical and psychological benefits of engagement with nature, art, and multisensory stimulation. Aspects of salutogenic design, and biophilia, warrant further research, perhaps within the umbrella afforded by an *ecohumanist* perspective—a perspective that fuses these concerns with ecological sustainability concerns (Verderber & Peters, 2017). Evidence-based research is warranted on attention restoration theory in ICU settings, perhaps combined with the phenomena of *nature-deficit disorder* as postulated by psychologist Richard Louv (2008). Also underrepresented were studies and essays on cost containment policy and best practices, ecological/resiliency determinants, or the role of advanced digital technologies, with none on robotics, and few on the subject of “Smart ICU” planning and design.

Suffice to say, pandemic considerations in intensive care built environments will continue to warrant research-based design attention. Cross-cultural, interdisciplinary collaborations will be essential between health policy experts, direct care providers, researchers, and the many specialists who plan and design these built environments. Architects, landscape architects, interior designers, artists, lighting, and equipment specialists have much insight and expertise to offer if hospital intensive care environments are to more therapeutically support the needs of their occupants in the future. It is expected the most important overarching design considerations will continue to center on mitigating adverse medical event occurrences and on improving the experience of all who work and receive care in these specialized environments worldwide.

Implications for Practice

- Evidence-based research findings are presented on the state of the art in ICU built environments over the past 15 years. This knowledge base has direct implications for facility planning, design, and management.
- Case studies in disaster response and pandemic healthcare facilities are reviewed, including architectural proposals and field hospitals constructed in response to the COVID-19 global pandemic.
- Prognostications for the future of ICU and related critical care built environments in hospital and field hospital settings are presented.

Declaration of Conflicting Interests

The author(s) declared no potential conflicts of interest with respect to the research, authorship, and/or publication of this article.

Funding

The author(s) disclosed receipt of the following financial support for the research, authorship, and/or publication of this article: This study was supported by John H. Daniels Faculty of Architecture, Landscape, and Design, University of Toronto.

ORCID iD

Stephen Verderber, ArchD  <https://orcid.org/0000-0001-8359-3144>

References

- Abo Elenien, O., & Nour, M. (2017). Applying flexibility spatial guidelines on an intensive care unit to increase its sustainability and life expectancy. *Port-Said Engineering Research Journal*, 21(2), 199–205.
- American Academy of Pediatrics & American College of Obstetricians and Gynecologists. (2002). *Guidelines for perinatal care* (5th ed.) <https://www.acog.org/clinical-information/physician-faqs/-/media/3a22e153b67446a6b31fb051e469187c.ashx>.
- American Academy of Pediatrics Committee on Environmental Health. (1997). Noise: A hazard for the fetus and newborn. *Pediatrics*, 100(4), 724–727.
- Apple, M. (2014). A comparative evaluation of Swedish intensive care patient rooms. *Health Environments Research & Design Journal*, 7(3), 78–93.
- Arenson, B. G., MacDonald, L. A., Grocott, H. P., Hiebert, B. M., & Arora, R. C. (2013). Effect of intensive care unit environment on in-hospital delirium after cardiac surgery. *The Journal of Thoracic and Cardiovascular Surgery*, 146(1), 172–178.

- Auerbach, A., O'Leary, K. J., Greysen, S. R., Harrison, J. D., Kripalani, S., Ruhnke, G. W., & Lee, T. (2020). Hospital ward adaptation during the COVID-19 pandemic: A national survey of academic medical centers. *Journal of Hospital Medicine, 15*(8), 483–488.
- Berglund, B. T., Lindvall, D. H., Schwelaand, K., & Goh, T. K. (1999). Guidelines for community noise. In *Protection of the human environment* (pp. 1–140). Geneva: World Health Organization.
- Beukeboom, C. J., Langeveld, D., & Tanja-Dijkstra, K. (2012). Stress-reducing effects of real and artificial nature in a hospital waiting room. *The Journal of Alternative and Complementary Medicine, 18*(4), 329–333.
- Blackwell, T., & Bosse, M. (2007). Use of an innovative design mobile hospital in the medical response to Hurricane Katrina. *Annals of Emergency Medicine, 49*(5), 580–588.
- Bloemendaal, A. L., Fluit, A. C., Jansen, W. M., Vriens, M. R., Ferry, T., Argaud, L., Amorim, J. M., Resende, A. C., Pascual, A., López-Cerero, L., Stefani, S., Castiglione, G., Evangelopoulou, P., Tsiplakou, S., Rinkes, I. H., & Verhoef, J. (2009). Acquisition and cross-transmission of *Staphylococcus aureus* in European intensive care units. *Infection Control and Hospital Epidemiology, 30*(2), 117–124.
- Bosch, S., Bledsoe, T., & Jenzarli, A. (2012). Staff perceptions before and after adding single-family rooms in the NICU. *Health Environments Research & Design Journal, 5*(4), 64–75.
- Bracco, D., Dubois, M. J., Bouali, R., & Eggimann, P. (2007). Single rooms may help to prevent nosocomial bloodstream infection and cross-transmission of methicillin-resistant *Staphylococcus aureus* in intensive care units. *Intensive Care Medicine, 33*(5), 836–840.
- Brandon, D., Ryan, D., & Barnes, A. (2007). Effect of environmental changes on noise in the NICU. *Neonatal Network, 26*(4), 213–218.
- Brown, K. K., & Gallant, D. (2006). Impacting patient outcomes through design: Acuity adaptable care/universal room design. *Critical Care Nursing Quarterly, 29*(4), 326–341.
- Brown, T. (2021, February 25). COVID-19 is probably going to end my career. *The New York Times*. Retrieved February 25, 2021, from <https://www.nytimes.com/2021/02/25/opinion/nursing-crisis-coronavirus.html>
- Burnweit, C., & Stylianos, S. (2011). Disaster response in a pediatric field hospital: Lessons learned in Haiti. *Journal of Pediatric Surgery, 46*(6), 1131–1139.
- Cai, H., & Zimring, C. (2012). Out of sight, out of reach: Correlating spatial metrics of nurse station typology with nurses' communication and co-awareness in an intensive care unit. *Proceedings of the 8th International Space Syntax Symposium, 36*(2), 381–391.
- Capolongo, S., Gola, M., Brambilla, A., Morganti, A., Mosca, E. I., & Barach, P. (2020). COVID-19 and Healthcare facilities: A decalogue of design strategies for resilient hospitals. *Acta Bio Med, 91*, 50–60.
- Carayon, P., Wooldridge, A., Hoonakker, P., Hundt, A. S., & Kelly, M. M. (2020). SEIPS 3.0: Human-centered design of the patient journey for patient safety. *Applied Ergonomics, 84*, 1–8.
- Caruso, P., Guardian, L., Tiengo, T., dos Santos, L. S., & Junior, P. M. (2014). ICU architectural design affects the delirium prevalence: A comparison between single-bed and multi bed rooms. *Critical Care Medicine, 42*(10), 2204–2210.
- Carvalho, W. B., Pedreira, M. L., & de Aguiar, M. A. L. (2005). Noise level in a pediatric intensive care unit. *Journal of Pediatrics, 81*(6), 495–498.
- Catrambone, C., Johnson, M. E., Mion, L. C., & Minnick, A. F. (2009). The design of adult acute care units in US hospitals. *Journal of Nursing Scholarship, 41*(1), 79–86.
- Cepeda, J. A., Whitehouse, T., Cooper, B., Hails, J., Jones, K., Kwaku, F., Taylor, L., Hayman, S., Cookson, B., Shaw, S., Kibbler, C., Singer, M., Bellingan, G., & Wilson, A. P. (2005). Isolation of patients in single rooms or cohorts to reduce the spread of MRSA in intensive care units: Prospective two-centre study. *Lancet, 364*, 295–304.
- Chawla, S., Barach, P., Dwaihy, M., Kamat, D., Shankaran, S., Panaitescu, B., Wang, B., & Natarajan, G. (2017). A targeted noise reduction observational study for reducing noise in a neonatal intensive unit. *Journal of Perinatology, 37*(9), 1060–1064.
- Chen, H. L., Chen, C. H., Wu, C. C., Huang, H. J., Wang, T. M., & Hsu, C. C. (2009). The influence of neonatal intensive care unit design on sound level. *Pediatrics & Neonatology, 50*(6), 270–274.
- Chen, L. K., Yuan, R. P., Ji, X. J., Lu, X. Y., Xiao, J., Tao, J. B., ... Jiang, L. Z. (2021). Modular

- composite building in urgent emergency engineering projects: A case study of accelerated design and construction of Wuhan Thunder God Mountain/Leishenshan hospital to COVID-19 pandemic. *Automation in Construction*, 124, 103555.
- Chen, S., Zhang, Z., Yang, J., Wang, J., Zhai, X., Bärnighausen, T., & Wang, C. (2020). Fangcang shelter hospitals: A novel concept for responding to public health emergencies. *The Lancet*, 395(10232), 1305–1314.
- Chen, Z., He, S., Li, F., Yin, J., & Chen, X. (2020). Mobile field hospitals, an effective way of dealing with COVID-19 in China: Sharing our experience. *BioScience Trends*, 14(2020), 212–214.
- Christensen, M. (2007). Noise levels in a general intensive care unit: A descriptive study. *Nursing in Critical Care*, 12(4), 188–197.
- Copeland, D., & Chambers, M. (2017). Effects of unit design on acute care nurses' walking distances, energy expenditure, and job satisfaction: A pre-post relocation study. *Health Environments Research & Design Journal*, 10(4), 22–36.
- Cordoza, M., Ulrich, R. S., Manulik, B. J., Gardiner, S. K., Fitzpatrick, P. S., Hazen, T. M., & Perkins, R. S. (2018). Impact of nurses taking daily work breaks in a hospital garden on burnout. *American Journal of Critical Care*, 27(6), 508–512.
- Davidson, J. E., Aslakson, R. A., Long, A. C., Puntillo, K. A., Kross, E. K., Hart, J., Cox, C. E., Wunsch, H., Wickline, M. A., Nunnally, M. E., Netzer, G., Kentish-Barnes, N., Sprung, C. L., Hartog, C. S., Coombs, M., Gerritsen, R. T., Hopkins, R. O., Franck, L. S., Skrobik, Y., Kon, A. A., ... Curtis, J. R. (2017). Guidelines for family-centered care in the neonatal, pediatric, and adult ICU. *Critical Care Medicine*, 45(1), 103–128.
- Davidson, J. E., Powers, K., Hedayat, K., Tieszen, M., Kon, A., Shepard, E., Spuhler, V., Todres, I., Levy, M., Barr, J., Ghandi, R., Hirsch, G., & Armstrong, D. (2007). Clinical practice guidelines for support of the family in the patient-centered intensive care unit: American College of Critical Care Medicine Task Force 2004–2005. *Critical Care Medicine*, 35(2), 605–622.
- Day, A., Haj-Bakri, S., Lubchansky, S., & Mehta, S. (2013). Sleep, anxiety and fatigue in family members of patients admitted to the intensive care unit: A questionnaire study. *Critical Care*, 17(3), 2–7.
- de Matos, L. B. N., Fumis, R. R. L., Nassar-Junior, A. P., Lacerda, F. H., & Caruso, P. (2020). Single-bed or multibed room designs influence ICU staff stress and family satisfaction, but do not influence ICU staff burnout. *Health Environments Research & Design Journal*, 13(2), 234–242.
- Denham, M. E., Bushehri, Y., & Lim, L. (2018). Through the eyes of the user: Evaluating neonatal intensive care unit design. *Health Environments Research & Design Journal*, 11(3), 49–65.
- des Déserts, M. D., Mathais, Q., Luft, A., Escarmont, J., & Pasquier, P. (2020). Conception and deployment of a 30-bed field military intensive care hospital in Eastern France during the 2020 COVID-19 pandemic. *Anaesthesia, Critical Care and Pain Medicine*, 39(3), 361–362.
- Doshi, A., Platt, Y., Dressen, J. R., Mathews, B. K., & Siy, J. C. (2020). Keep calm and log on: Telemedicine for COVID-19 pandemic response. *Journal of Hospital Medicine*, 15(5), 302–304.
- Fang, D., Pan, S., Li, Z., Yuan, T., Jiang, B., Gan, D., & Liu, Z. (2020). Large-scale public venues as medical emergency sites in disasters: Lessons from COVID-19 and the use of Fangcang shelter hospitals in Wuhan, China. *British Medical Journal of Global Health*, 5(6), 1–7.
- Fay, L., Cai, H., & Real, K. (2019). A systematic literature review of empirical studies on decentralized nursing stations. *Health Environments Research & Design Journal*, 12(1), 44–68.
- Flinn, J. B., Hynes, N. A., Sauer, L. M., Maragakis, L. L., & Garibaldi, B. T. (2020). The role of dedicated biocontainment patient care units in preparing for COVID-19 and other infectious disease outbreaks. *Infection Control & Hospital Epidemiology*, 12(2), 1–4.
- Fortis, S., Weinert, C., Bushinski, R., Koehler, A. G., & Beilman, G. (2014). A health system-based critical care program with a novel tele-ICU: Implementation, cost, and structure details. *Journal of the American College of Surgeons*, 219(4), 676–683.
- Franck, L. S., Ferguson, D., Fryda, S., & Rubin, N. (2015). The child and family hospital experience: Is it influenced by family accommodation? *Medical Care Research and Review*, 2(4), 419–437.
- Fridh, I., Forsberg, A., & Bergbom, I. (2009). Doing one's utmost: Nurses' descriptions of caring for dying patients in an intensive care environment. *Intensive Critical Care Nursing*, 25(5), 233–241.

- Grinde, B., & Patil, G. G. (2009). Biophilia: Does visual contact with nature impact on health and well-being? *International Journal of Environmental Research and Public Health*, 6(9), 2332–2343.
- Gurses, A. P., & Carayon, P. (2009). Exploring performance obstacles of intensive care nurses. *Applied Ergonomics*, 40(3), 509–518.
- Hadi, K., & Zimring, C. (2016). Design to improve visibility: Impact of corridor width and unit shape. *Health Environments Research & Design Journal*, 9(4), 35–49.
- Halpern, N. A., Anderson, D. C., & Kesecioglu, J. (2017). ICU design in 2050: Looking into the crystal ball. *Intensive Care Medicine*, 43(5), 690–692.
- Hamilton, D. K. (2013). Research informed design supports evidence-based ICU medicine. *Health Environments Research & Design Journal*, 6(4), 97–100.
- Hamilton, D. K. (2020). Design for critical care. In S. Arath & S. Farzan (Eds.), *Design for health* (pp. 129–145). Academic Press.
- Hamilton, D. K., Swoboda, S. M., Lee, J. T., & Anderson, D. C. (2018). Decentralization: The corridor is the problem, not the alcove. *Critical Care Nursing Quarterly*, 41(1), 3–9.
- Harris, D. D., Shepley, M. M., White, R. D., Kolberg, K. J., & Harrell, J. W. (2006). The impact of single family room design on patients and caregivers: Executive summary. *Journal of Perinatology*, 26(3), S38–S48.
- Huffling, K., & Schenk, E. (2014). Environmental sustainability in the intensive care unit: Challenges and solutions. *Critical Care Nursing Quarterly*, 37(3), 235–250.
- Huisman, E. R., Morales, E., Van Hoof, J., & Kort, H. S. (2012). Healing environment: A review of the impact of physical environmental factors on users. *Building and Environment*, 58(2), 70–80.
- Huynh, T. G., Owens, R. L., & Davidson, J. E. (2020). Impact of built design on nighttime family presence in the intensive care unit. *Health Environments Research & Design Journal*, 13(1), 106–113.
- Iyendo, T. O., Uwajeh, P. C., & Ikenna, E. S. (2016). The therapeutic impacts of environmental design interventions on wellness in clinical settings: A narrative review. *Complementary Therapies in Clinical Practice*, 24(4), 174–188.
- Johansson, L., Bergbom, I., Wayne, K. P., Ryherd, E., & Lindahl, B. (2012). The sound environment in an ICU patient room: A content analysis of sound levels and patient experiences. *Intensive and Critical Care Nursing*, 28(5), 269–279.
- Jongerden, I. P., Slooter, A. J., Peelen, L. M., Wessels, H., Ram, C. M., Kesecioglu, J., & Dijk, D. V. (2013). Effect of intensive care environment on family and patient satisfaction: A before–after study. *Intensive Care Medicine*, 39(9), 1626–1634.
- Kawai, Y., Weatherhead, J. R., Traube, C., Owens, T. A., Shaw, B. E., Fraser, E. J., & Baker, L. A. (2019). Quality improvement initiative to reduce pediatric intensive care unit noise pollution with the use of a pediatric delirium bundle. *Journal of Intensive Care Medicine*, 34(5), 383–390.
- Keenan, J. M. (2020). COVID, resilience, and the built environment. *Environment Systems and Decisions*, 40(2020), 1–6.
- Kesecioglu, J., Schneider, M. M., Van der Kooij, A. W., & Bion, J. (2012). Structure and function: Planning a new ICU to optimize patient care. *Current Opinion in Critical Care*, 18(6), 688–692.
- Kohn, R., Harhay, M. O., Cooney, E., Small, D. S., & Halpern, S. D. (2013). Do windows or natural views affect outcomes or costs among patients in ICUs? *Critical Care Medicine*, 41(7), 1645–1655.
- Kol, E., Demircan, A., Erdoan, A., Gencer, Z., & Erengin, H. (2015). The effectiveness of measures aimed at noise reduction in an intensive care unit. *Workplace Health & Safety*, 63(12), 539–545.
- Kramer, B., Joshi, P., & Heard, C. (2016). Noise pollution levels in the pediatric intensive care unit. *Journal of Critical Care*, 36, 111–115.
- Kreiss, Y., Merin, O., Peleg, K., Levy, G., Vinker, S., & Sagi, R. (2010). Early disaster response in Haiti: The Israeli field hospital experience. *Annals of Internal Medicine*, 153(1), 45–48.
- Kwan, M. A. (2011). Acuity-adaptable nursing care: Exploring its place in designing the future patient room. *Health Environments Research & Design Journal*, 5(1), 77–93.
- Lasky, R. E., & Williams, A. L. (2009). Noise and light exposures for extremely low birth weight newborns during their stay in the neonatal intensive care unit. *Pediatrics*, 123(2), 540–546.
- Leaf, D. E., Homel, P., & Factor, P. H. (2010). Relationship between ICU design and mortality. *Chest*, 137(5), 1022–1027.
- Lee, J. S., Roberts, S., Götsch, K., Moeller, U., & Hawryluck, L. (2019). Caring for critically ill patients in humanitarian settings. *American Journal*

- of Respiratory and Critical Care Medicine*, 199(5), 572–580.
- Lenaghan, P. A., & Schwedhelm, M. (2015). Nebraska biocontainment unit design and operations. *JONA: The Journal of Nursing Administration*, 45(6), 298–301.
- Levin, P. D., Golovanevski, M., Moses, A. E., Sprung, C. L., & Benenson, S. (2011). Improved ICU design reduces acquisition of antibiotic-resistant bacteria: A quasi-experimental observational study. *Critical Care*, 15(5), 2–9.
- Louri, N. A., Alkhan, J. A., Isa, H. H., Asad, Y., Alsharooqi, A., Alomari, K. A., Hasan, N. K., Al Khalifa, F. B. K., Ahmed, G. F., Alasmj, M. Y., Al-Khalifa, D. K., & Al-Khalifa, D. K. (2020). Establishing a 130-bed field intensive care unit to prepare for COVID-19 in 7 days in Bahrain Military Hospital. *Disaster Medicine and Public Health Preparedness*, 14(2020), 1–10.
- Louv, R. (2008). *Last child in the woods: Why children need nature, how it was taken from them, and how to get it back*. Algonquin Books.
- Lu, Y., Ossmann, M. M., Leaf, D. E., & Factor, P. H. (2014). Patient visibility and ICU mortality: A conceptual replication. *Health Environments Research & Design Journal*, 7(2), 92–103.
- Lu, Y., & Zimring, C. (2011). Can intensive care staff see their patients? An improved visibility analysis methodology. *Environment and Behavior*, 44(6), 861–876.
- Luetz, A., Weiss, B., Penzel, T., Fietze, I., Glos, M., Wernecke, K. D., & Spies, C. (2016). Feasibility of noise reduction by a modification in ICU environment. *Physiological Measurement*, 37(7), 1041.
- Macdonald, M. E., Liben, S., Carnevale, F. A., & Cohen, S. R. (2012). An office or a bedroom? Challenges for family-centered care in the pediatric intensive care unit. *Journal of Child Health Care*, 16(3), 237–249.
- Macedo, I. S. C., Mateus, D. C., Costa, E. D. M. G. C., Asprino, A. C. L., & Lourenço, E. A. (2009). Noise assessment in intensive care units. *Brazilian Journal of Otorhinolaryngology*, 75(6), 844–846.
- Malenbaum, S., Keefe, F. J., Williams, A., Ulrich, R., & Somers, T. J. (2008). Pain in its environmental context: Implications for designing environments to enhance pain control. *Pain*, 134(3), 241.
- Marshall-Baker, A. (2006). Human and environmental health: Sustainable design for the NICU. *Journal of Perinatology*, 26(3), S31–S33.
- Matook, S., Sullivan, M., Salisbury, A., Miller, R., & Lester, B. (2010). Variations of ICU sound by location and time of day. *Neonatal Network*, 29(2), 87–95.
- McGain, F., & Naylor, C. (2014). Environmental sustainability in hospitals—A systematic review and research agenda. *Journal of Health Services Research and Policy*, 19(4), 245–252.
- Minton, C., & Batten, L. (2015). Rethinking the intensive care environment: Considering nature in nursing practice. *Journal of Clinical Nursing*, 25(1–2), 269–277.
- Morag, I., & Ohlsson, A. (2016). Cycled light in the intensive care unit for preterm and low birth weight infants. *Cochrane Database of Systematic Reviews*, 2016(8), CD006982.
- O'Hara, S., Klar, R. T., Patterson, E. S., Morris, N. S., Ascenzi, J., Fackler, J. C., & Perry, D. J. (2018). Macrocognition in the healthcare built environment (mHCBE): A focused ethnographic study of “Neighborhoods” in a pediatric intensive care unit. *Health Environments Research & Design*, 11(2), 104–123.
- Ong, T., Ruppert, M., Rashidi, P., Ozrazgat-Baslanti, T., Suvajdzic, M., & Bihorac, A. (2019). *The DREAMS project: Improving the intensive care patient experience with virtual reality*. arXiv preprint arXiv:1906.11706. <https://arxiv.org/abs/1906.11706>.
- Owens, P. J., Forgione, A., Jr., & Briggs, S. (2005). Challenges of international disaster relief: Use of a deployable rapid assembly shelter and surgical hospital. *Disaster Management & Response*, 3(1), 11–16.
- Paterson, J., Berry, P., Ebi, K., & Varangu, L. (2014). Health care facilities resilient to climate change impacts. *International Journal of Environmental Research and Public Health*, 11(12), 13097–13116.
- Pati, D., Harvey, T. E., Jr., & Barach, P. (2008). Relationships between exterior views and nurse stress: An exploratory examination. *Health Environments Research & Design Journal*, 1(2), 27–38.
- Pati, D., Harvey, T. E., Jr., Redden, P., Summers, B., & Pati, S. (2015). An empirical examination of the impacts of decentralized nursing unit design. *Health Environments Research & Design Journal*, 8(2), 56–70.

- Peterson, M. J., Woerhle, T., Harry, M., Heger, A. M. C., Gerchman-Smith, M., Vogel, L., Hughes, C., & McCarty, C. (2020). Family satisfaction in a neuro trauma ICU. *Nursing Critical Care, 15*(7), 1–7.
- Pettit, N. R., Wood, T., Lieber, M., & O'Mara, M. S. (2014). Intensive care unit design and mortality in trauma patients. *Journal of Surgical Research, 190*(2), 640–646.
- Pucher, P. H., Batrick, N., Taylor, D., Chaudery, M., Cohen, D., & Darzi, A. (2014). Virtual-world hospital simulation for real-world disaster response. *Journal of Trauma and Acute Care Surgery, 77*(2), 315–321.
- Quaglia, C. P., Yu, N., Thrall, A. P., & Paolucci, S. (2014). Balancing energy efficiency and structural performance through multi-objective shape optimization: Case study of a rapidly deployable origami-inspired shelter. *Energy and Buildings, 82*(3), 733–745.
- Rashid, M. (2010). Environmental design for patient families in intensive care units. *Journal of Health-care Engineering, 1*(3), 367–398.
- Rashid, M. (2011). Technology and the future of intensive care unit design. *Critical Care Nursing Quarterly, 34*(4), 332–360.
- Rashid, M. (2014). Space allocation in the award-winning adult ICUs of the last two decades (1993–2012): An exploratory study. *Health Environments Research & Design Journal, 7*(2), 29–56.
- Rashid, M., Boyle, D. K., & Crosser, M. (2014). Network of spaces and interaction-related behaviors in adult intensive care units. *Behavioral Sciences, 4*(4), 487–510.
- Real, K., Bardach, S. H., & Bardach, D. R. (2016). The role of the built environment: How decentralized nurse stations shape communication, patient care processes, and patient outcomes. *Health Communication, 32*(12), 1557–1570.
- Reynolds, K., Sexton, J., Garavito, F., Anderson, B., & Ivaska, J. (2020). Whole-room hypochlorous acid atomizing disinfection system on healthcare surface contamination and transfer. *American Journal of Infection Control, 48*(2), S22–S23.
- Rippin, A. S., Zimring, C., Samuels, O., & Denham, M. E. (2015). Finding a middle ground: Exploring the impact of patient-and family-centered design on nurse–family interactions in the neuro ICU. *Health Environments Research & Design Journal, 9*(1), 80–98.
- Rompaey, B. V., Elseviers, M. M., Schuurmans, M. J., Shortridge-Baggett, L. M., Truijien, S., & Bossaert, L. (2009). Risk factors for delirium in intensive care patients: A prospective cohort study. *Critical Care, 13*(3), 2–12.
- Rubert, R., Long, L. D., & Hutchinson, M. L. (2007). Creating a healing environment in the ICU. *Critical Care Nursing, 1*(3), 27–39.
- Rybkowski, Z. K., Shepley, M. M., & Ballard, H. G. (2012). Target value design: Applications to newborn intensive care units. *Health Environments Research & Design Journal, 5*(4), 5–22.
- Ryherd, E. E., Wayne, K. P., & Ljungkvist, L. (2008). Characterizing noise and perceived work environment in a neurological intensive care unit. *The Journal of the Acoustical Society of America, 123*(2), 747–756.
- Santos, A. F., Gaspar, P. D., Hamandosh, A., Aguiar, E. B. D., Guerra Filho, A. C., & Souza, H. J. L. D. (2020). Best practices on HVAC design to minimize the risk of COVID-19 infection within indoor environments. *Brazilian Archives of Biology and Technology, 23*(2020), 63.
- Sehulster, L. M., Chinn, R. Y. W., Arduino, M. J., Carpenter, J., Donlan, R., Ashford, D., Besser, R., Fields, B., McNeil, M. M., Whitney, C., Wong, S., Juranek, D., & Cleveland, J. (2004). *Guidelines for environmental infection control in health-care facilities: Recommendations from CDC and the health-care infection control practices advisory committee (HICPAC)*. American Society for Healthcare Engineering/American Hospital Association.
- Sessler, C. N. (2014). Evolution of ICU design: Smarter is better. *Chest, 145*(2), 205–206.
- Shepley, M. M., Gerbi, R. P., Watson, A. E., Imgrund, S., & Sagha-Zadeh, R. (2012). The impact of daylight and views on ICU patients and staff. *Health Environments Research & Design Journal, 5*(2), 46–60.
- Shepley, M. M., Song, Y., & Marshall-Baker, A. (2016). Creating an environmentally sustainable neonatal intensive care unit. *Newborn and Infant Nursing Review, 16*(4), 213–217.
- Simons, K. S., Laheij, R. F., Boogaard, M. V., Moviat, M. A., Paling, A. J., Polderman, F. N., & Jager, C. D. (2016). Dynamic light application therapy to reduce the incidence and duration of delirium

- in intensive-care patients: A randomised controlled trial. *The Lancet—Respiratory Medicine*, 4(3), 194–202.
- Stevens, D. C., Helseth, C. C., Khan, M. A., Munson, D. P., & Smith, T. J. (2010). Neonatal intensive care nursery staff perceive enhanced workplace quality with the single-family room design. *Journal of Perinatology*, 30(5), 352–358.
- Stevens, D. C., Helseth, C. C., Thompson, P. A., Pottala, J. V., Khan, M. A., & Munson, D. P. (2012). A comprehensive comparison of open-bay and single-family-room neonatal intensive care units at Stanford Children’s Hospital. *Health Environments Research & Design Journal*, 5(4), 23–39.
- Stevens, D. C., Khan, M. A., Munson, D. P., Reid, E. J., Helseth, C. C., & Buggy, J. (2007). The impact of architectural design upon the environmental sound and light exposure of neonates who require intensive care: An evaluation of the Boekelheide Neonatal Intensive Care Nursery. *Journal of Perinatology*, 27(S2), S20–S28.
- Stichler, J. F. (2012). The new standard: Single family room design. *The Journal of Nursing Administration*, 42(10), 447–450.
- Stiller, A., Schröder, C., Gropmann, A., Schwab, F., Behnke, M., Geffers, C., & Gastmeier, P. (2017). ICU ward design and nosocomial infection rates: A cross-sectional study in Germany. *Journal of Hospital Infection*, 95(1), 71–75.
- Stremler, R., Dhukai, Z., Pullenayegum, E., Weston, J., Wong, L., & Parshuram, C. (2014). Sleep, sleepiness, and fatigue outcomes for parents of critically ill children. *Pediatric Critical Care Medicine*, 15(2), e56–e65.
- Sundberg, F., Olausson, S., Fridh, I., & Lindahl, B. (2017). Nursing staff’s experiences of working in an evidence-based designed ICU patient room—An interview study. *Intensive and Critical Care Nursing*, 43, 75–80.
- Swanson, J. R., Peters, C., & Lee, B. H. (2013). NICU redesign from open ward to private room: A longitudinal study of parent and staff perceptions. *Journal of Perinatology*, 33(6), 466–469.
- Tanja-Dijkstra, K., Pieterse, M., & Pruyn, A. (2008). Stress-reducing effects of indoor plants in the built healthcare environment: The mediating role of perceived attractiveness. *Preventive Medicine*, 47(1), 279–283.
- Teltsch, D. Y., Hanley, J., Loo, V., Goldberg, P., Gursahaney, A., & Buckeridge, D. L. (2011). Infection acquisition following intensive care unit room privatization. *Archives of Internal Medicine*, 171(1), 32–38.
- Thompson, D. R., Hamilton, D. K., Cadenhead, C. D., Swoboda, S. M., Schwindel, S. M., Anderson, D. C., & Harvey, M. A. (2012). Guidelines for intensive care unit design. *Critical Care Medicine*, 40(5), 1586–1600.
- Ulrich, R. L., Zimring, C., Zhu, X., DuBose, J., Seo, H. B., Choi, Y. S., Quan, X., & Joseph, A. (2008). A review of the research on evidence-based health-care design. *Health Environments Research & Design Journal*, 1(3), 61–125.
- Ulrich, R. S., Cordoza, M., Gardiner, S. K., Manulik, B. J., Fitzpatrick, P. S., Hazen, T. M., & Perkins, R. S. (2020). ICU patient family stress recovery during breaks in a hospital garden and indoor environments. *Health Environments Research & Design Journal*, 13(2), 83–102.
- Ulrich, R. S., Zimring, C., Quan, X., Joseph, A., & Choudhary, R. (2004). *The role of the physical environment in the hospital of the 21st century: A once-in-a-lifetime opportunity*. The Center for Health Design. Retrieved November 12, 2020, from https://www.healthdesign.org/sites/default/role_physical_environment_in_the_21st_century_hospital_0.pdf
- Valentin, A., & Ferdinande, P. (2011). Recommendations on basic requirements for intensive care units: Structural and organizational aspects. *Intensive Care Medicine*, 37(10), 1575.
- Verceles, A. C., Liu, X., Terrin, M. L., Scharf, S. M., Shanholtz, C., Harris, A., & Netzer, G. (2013). Ambient light levels and critical care outcomes. *Journal of Critical Care*, 28(1), 110–118.
- Verderber, S. (2010). *Innovations in hospital architecture*. Routledge.
- Verderber, S. (2021). *Pandemical Healthcare Architecture and Social Responsibility—COVID-19 and Beyond* (Centre for Design + Health Innovation White Paper). University of Toronto. Retrieved February 26, 2021, from <https://www.daniels.utoronto.ca/work/research/centre-design-health-innovation.htm>
- Verderber, S., & Peters, P. (2017). Territories of engagement in the design of eco-humanist health-care environments. *Health Environments Research & Design Journal*, 10(2), 104–123.

- Wallace, D. J., Seymour, C. W., & Kahn, J. M. (2017). Hospital-level changes in adult ICU bed supply in the United States. *Critical Care Medicine*, *45*(1), e67–e76.
- Wang, Z., Downs, B., Farrell, A., Cook, K., Hourihan, P., & McCreery, S. (2013). Role of a service corridor in ICU noise control, staff stress, and staff satisfaction: Environmental research of an academic medical center. *Health Environments Research & Design Journal*, *6*(3), 80–94.
- White, R. D., Smith, J. A., & Shepley, M. M. (2013). Recommended standards for newborn ICU design. *Journal of Perinatology*, *33*(1), 2–16.
- Wosik, J., Fudim, M., Cameron, B., Gellad, Z. F., Cho, A., Phinney, D., Curtis, S., Roman, M., Poon, E. G., Ferranti, J., & Katz, J. N. (2020). Telehealth transformation: COVID-19 and the rise of virtual care. *Journal of the American Medical Informatics Association*, *27*(6), 957–962.
- Wunsch, H., Gershengorn, H., Mayer, S. A., & Claassen, J. (2011). The effect of windowed rooms on critically ill patients with subarachnoid hemorrhage admitted to intensive care. *Critical Care*, *15*(2), R81.
- Zborowsky, T., & Hellmich, L. B. (2011). Impact of place on people and process: The integration of research on the built environment in the planning and design of critical care areas. *Critical Care Nursing Quarterly*, *34*(4), 268–281.
- Zhou, M., Chen, Y., Su, X., & An, L. (2020). Rapid construction and advanced technology for a Covid-19 field hospital in Wuhan, China. In *Proceedings of the Institution of Civil Engineers-Civil Engineering*, *174*(1), 29–34.
- Zimring, C., Denham, M. E., Jacob, J. T., Cowan, D. Z., Do, E., Hall, K., Kamerow, D., Kasali, A., & Steinberg, J. P. (2013). Evidence-based design of healthcare facilities: Opportunities for research and practice in infection prevention. *Infection Control & Hospital Epidemiology*, *34*(5), 514–516.
- Zores, C., Dufour, A., Pebayle, T., Dahan, I., Astruc, D., & Kuhn, P. (2018). Observational study found that even small variations in light can wake up very preterm infants in a neonatal intensive care unit. *Acta Paediatrica*, *107*, 1191–1197.
- Zores-Koenig, C., Kuhn, P., Caeymaex, L., Allen, A., Berne-Audeoud, F., Bouvard, C., Brandicourt, A., Casper, C., Denoual, H., Duboz, M., Evrard, A., Fichtner, C., Fischer-Fumeaux, C., Girard, L., Gonnaud, F., Haumont, D., Hüppi, P., Knezovic, N., Laprugne-Garcia, E., & Zana-Taieb, E. (2020). Recommendations on neonatal light environment from the French Neonatal Society. *Acta Paediatrica*, *109*(7), 1292–1301.